

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Πέμπτη, 7 Μαΐου 2026			
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ρ Ε Π Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
			Πέμπτη, 7 Μαΐου 2026	00:00	0,890		1		
01:00	0,822			1					
02:00	0,797			1					
03:00	0,778			1					
04:00	0,758			1					
05:00	0,752			1					
06:00	0,771			1					
07:00	0,820			1					
08:00	0,887			1					
09:00	0,927			1					
10:00	0,915			1					
11:00	0,900			1					
12:00	0,891			1					
13:00	0,882			1					
14:00	0,880			1					
15:00	0,878			1					
16:00	0,887			1					
17:00	0,921			1					
18:00	1,000			1	1				
19:00	1,089			1	1				
20:00	1,166			1	1				
21:00	1,161			1	1				
22:00	1,092			1	1				
23:00	0,999		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Παρασκευή, 8 Μαΐου 2026			
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,809			1					
02:00	0,775			1					
03:00	0,774			1					
04:00	0,766			1					
05:00	0,770			1					
06:00	0,790			1					
07:00	0,833			1					
08:00	0,887			1					
09:00	0,936			1					
10:00	0,955			1					
11:00	0,950			1					
12:00	0,917			1					
13:00	0,908			1					
14:00	0,924			1					
15:00	0,952			1					
16:00	0,997		1	1					
17:00	1,039		1	1					
18:00	1,078		1	1					
19:00	1,142		1	1					
20:00	1,195		1	1					
21:00	1,189		1	1					
22:00	1,121		1	1					
23:00	1,010		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Σάββατο, 9 Μαΐου 2026			
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,824			1					
02:00	0,785			1					
03:00	0,778			1					
04:00	0,778			1					
05:00	0,791			1					
06:00	0,824			1					
07:00	0,878			1					
08:00	0,930			1					
09:00	0,967			1					
10:00	0,986		1	1					
11:00	0,996		1	1					
12:00	0,994		1	1					
13:00	0,972			1					
14:00	0,956			1					
15:00	0,945			1					
16:00	0,949			1					
17:00	0,971			1					
18:00	1,021		1	1					
19:00	1,096		1	1					
20:00	1,181		1	1					
21:00	1,197		1	1					
22:00	1,137		1	1					
23:00	1,026		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Κυριακή, 10 Μαΐου 2026			
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ρ Ε Ρ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,827			1					
02:00	0,802			1					
03:00	0,797			1					
04:00	0,792			1					
05:00	0,793			1					
06:00	0,821			1					
07:00	0,864			1					
08:00	0,921			1					
09:00	0,965			1					
10:00	0,966			1					
11:00	0,966			1					
12:00	0,944			1					
13:00	0,909			1					
14:00	0,883			1					
15:00	0,869			1					
16:00	0,871			1					
17:00	0,891			1					
18:00	0,933			1					
19:00	1,001		1	1					
20:00	1,090		1	1					
21:00	1,118		1	1					
22:00	1,077		1	1					
23:00	0,988		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Δευτέρα, 11 Μαΐου 2026			
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,767			1					
02:00	0,744			1					
03:00	0,746			1					
04:00	0,748			1					
05:00	0,754			1					
06:00	0,790			1					
07:00	0,845			1					
08:00	0,895			1					
09:00	0,947			1					
10:00	0,937			1					
11:00	0,921			1					
12:00	0,911			1					
13:00	0,896			1					
14:00	0,881			1					
15:00	0,880			1					
16:00	0,895			1					
17:00	0,923			1					
18:00	0,976			1					
19:00	1,056		1	1					
20:00	1,140		1	1					
21:00	1,153		1	1					
22:00	1,093		1	1					
23:00	0,965		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Τρίτη, 12 Μαΐου 2026			
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
ΑΡΡΕΤΗ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,772			1					
02:00	0,740			1					
03:00	0,734			1					
04:00	0,729			1					
05:00	0,728			1					
06:00	0,766			1					
07:00	0,838			1					
08:00	0,900			1					
09:00	0,940			1					
10:00	0,957			1					
11:00	0,958			1					
12:00	0,944			1					
13:00	0,924			1					
14:00	0,910			1					
15:00	0,900			1					
16:00	0,910			1					
17:00	0,943			1					
18:00	1,006		1	1					
19:00	1,088		1	1					
20:00	1,170		1	1					
21:00	1,178		1	1					
22:00	1,104		1	1					
23:00	0,954			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Τετάρτη, 13 Μαΐου 2026			
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Α Ρ Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,788			1					
02:00	0,750			1					
03:00	0,738			1					
04:00	0,730			1					
05:00	0,731			1					
06:00	0,772			1					
07:00	0,844			1					
08:00	0,890			1					
09:00	0,908			1					
10:00	0,907			1					
11:00	0,897			1					
12:00	0,885			1					
13:00	0,877			1					
14:00	0,870			1					
15:00	0,866			1					
16:00	0,873			1					
17:00	0,912			1					
18:00	0,991			1					
19:00	1,099		1	1					
20:00	1,189		1	1					
21:00	1,191		1	1					
22:00	1,113		1	1					
23:00	0,975		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης