

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 29 Μαΐου 2026				
Αποδιδόμενη Ισχύς (ΜW)		1,000	1,100	1,100	1,100	1,100	1,100	1,000	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G2	G3	G4	G5	G6	G7
			Παρασκευή, 29 Μαΐου 2026	00:00	1,373	1	1		
01:00	1,288	1		1					
02:00	1,224	1		1					
03:00	1,194	1		1					
04:00	1,196	1		1					
05:00	1,244	1		1					
06:00	1,316	1		1					
07:00	1,414	1		1					
08:00	1,518	1		1					
09:00	1,576	1		1					
10:00	1,530	1		1					
11:00	1,485	1		1					
12:00	1,502	1		1					
13:00	1,518	1		1					
14:00	1,455	1		1					
15:00	1,308	1		1					
16:00	1,262	1		1					
17:00	1,331	1		1					
18:00	1,489	1		1					
19:00	1,701	1		1			1		
20:00	1,866	1		1			1		
21:00	1,887	1		1			1		
22:00	1,724			1			1		
23:00	1,555			1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 30 Μαΐου 2026				
Αποδιδόμενη Ισχύς (MW)		1,000	1,100	1,100	1,100	1,100	1,100	1,000	
Η Ρ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
			Σάββατο, 30 Μαΐου 2026	00:00	1,396		1		
01:00	1,328			1			1		
02:00	1,279			1			1		
03:00	1,260			1			1		
04:00	1,256			1			1		
05:00	1,262			1			1		
06:00	1,271			1			1		
07:00	1,296			1			1		
08:00	1,381			1			1		
09:00	1,458			1			1		
10:00	1,466			1			1		
11:00	1,450			1			1		
12:00	1,449			1			1		
13:00	1,432			1			1		
14:00	1,364			1			1		
15:00	1,262			1			1		
16:00	1,212			1			1		
17:00	1,325			1			1		
18:00	1,530			1			1		
19:00	1,729			1			1		
20:00	1,840			1			1		
21:00	1,776			1			1		
22:00	1,571			1			1		
23:00	1,417			1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 31 Μαΐου 2026				
Αποδιδόμενη Ισχύς (MW)		1,000	1,100	1,100	1,100	1,100	1,100	1,000	
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 31 Μαΐου 2026	00:00	1,331		1			1		
	01:00	1,286		1			1		
	02:00	1,254		1			1		
	03:00	1,226		1			1		
	04:00	1,198		1			1		
	05:00	1,170		1			1		
	06:00	1,196		1			1		
	07:00	1,241		1			1		
	08:00	1,370		1			1		
	09:00	1,453		1			1		
	10:00	1,467		1			1		
	11:00	1,443		1			1		
	12:00	1,411		1			1		
	13:00	1,360		1			1		
	14:00	1,265		1			1		
	15:00	1,161		1			1		
	16:00	1,140		1			1		
	17:00	1,246		1			1		
	18:00	1,429		1			1		
	19:00	1,605		1			1		
	20:00	1,728		1			1		
	21:00	1,677		1			1		
	22:00	1,497		1			1		
	23:00	1,374		1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 1 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (MW)		1,000	1,100	1,100	1,100	1,100	1,100	1,000	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
01:00	1,109		1			1			
02:00	1,067		1			1			
03:00	1,075		1			1			
04:00	1,107		1			1			
05:00	1,141		1			1			
06:00	1,214		1			1			
07:00	1,335		1			1			
08:00	1,440		1			1			
09:00	1,467		1			1			
10:00	1,461		1			1			
11:00	1,450		1			1			
12:00	1,454		1			1			
13:00	1,442		1			1			
14:00	1,338		1			1			
15:00	1,179		1			1			
16:00	1,117		1			1			
17:00	1,207		1			1			
18:00	1,398		1			1			
19:00	1,582		1			1			
20:00	1,711		1			1			
21:00	1,673		1			1			
22:00	1,481		1			1			
23:00	1,339		1			1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τρίτη, 2 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,000	1,100	1,100	1,100	1,100	1,100	1,000	
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
01:00	1,202		1			1			
02:00	1,180		1			1			
03:00	1,188		1			1			
04:00	1,210		1			1			
05:00	1,237		1			1			
06:00	1,298		1			1			
07:00	1,413		1			1			
08:00	1,508		1			1			
09:00	1,516		1			1			
10:00	1,489		1			1			
11:00	1,469		1			1			
12:00	1,514		1			1			
13:00	1,538		1			1			
14:00	1,432		1			1			
15:00	1,251		1			1			
16:00	1,186		1			1			
17:00	1,270		1			1			
18:00	1,455		1			1			
19:00	1,656		1			1			
20:00	1,820		1			1			
21:00	1,795		1			1			
22:00	1,597		1			1			
23:00	1,426		1			1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τετάρτη, 3 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,000	1,100	1,100	1,100	1,100	1,100	1,000	
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
			Τετάρτη, 3 Ιουνίου 2026	00:00	1,368		1		
01:00	1,305			1			1		
02:00	1,274			1			1		
03:00	1,275			1			1		
04:00	1,274			1			1		
05:00	1,285			1			1		
06:00	1,332			1			1		
07:00	1,464			1			1		
08:00	1,580			1			1		
09:00	1,607			1			1		
10:00	1,583			1			1		
11:00	1,587			1			1		
12:00	1,681			1			1		
13:00	1,771			1			1		
14:00	1,674			1			1		
15:00	1,433			1			1		
16:00	1,290			1			1		
17:00	1,319			1			1		
18:00	1,491			1			1		
19:00	1,727			1			1		
20:00	1,931	1		1			1		
21:00	1,930	1		1			1		
22:00	1,729	1					1		
23:00	1,521	1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 4 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (MW)		1,000	1,100	1,100	1,100	1,100	1,100	1,000	
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 4 Ιουνίου 2026	00:00	1,504			1		1		
	01:00	1,441			1		1		
	02:00	1,408			1		1		
	03:00	1,373			1		1		
	04:00	1,358			1		1		
	05:00	1,349			1		1		
	06:00	1,377			1		1		
	07:00	1,529			1		1		
	08:00	1,640			1		1		
	09:00	1,669			1		1		
	10:00	1,649			1		1		
	11:00	1,643			1		1		
	12:00	1,719			1		1		
	13:00	1,803			1		1		
	14:00	1,715			1		1		
	15:00	1,493			1		1		
	16:00	1,362			1		1		
	17:00	1,404			1		1		
	18:00	1,574			1		1		
	19:00	1,798			1		1		
	20:00	1,997	1		1		1		
	21:00	1,986	1		1		1		
	22:00	1,786			1		1		
	23:00	1,585			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης