

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 24 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Τετάρτη, 24 Ιουνίου 2026	00:00	91	1		1	
01:00	86	1			1				
02:00	82				1				
03:00	80				1				
04:00	79				1				
05:00	77				1				
06:00	75				1				
07:00	75				1				
08:00	80				1				
09:00	87	1			1				
10:00	94	1			1				
11:00	100	1			1				
12:00	102	1			1				
13:00	104	1			1				
14:00	104	1			1				
15:00	103	1			1				
16:00	101	1			1				
17:00	99	1			1				
18:00	98	1			1				
19:00	96	1			1				
20:00	96	1			1				
21:00	100	1			1				
22:00	101	1			1				
23:00	97	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 25 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Πέμπτη, 25 Ιουνίου 2026	00:00	97	1		1	
01:00	91	1			1				
02:00	87	1			1				
03:00	86	1			1				
04:00	85	1			1				
05:00	84	1			1				
06:00	82	1			1				
07:00	84	1			1				
08:00	90	1			1				
09:00	99	1			1				
10:00	107	1			1				
11:00	112	1			1				
12:00	115	1			1				
13:00	114	1			1				
14:00	111	1			1				
15:00	109	1			1				
16:00	106	1			1				
17:00	103	1			1				
18:00	100	1			1				
19:00	94	1			1				
20:00	96	1			1				
21:00	100	1			1				
22:00	104	1			1				
23:00	101	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 26 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Παρασκευή, 26 Ιουνίου 2026	00:00	98	1		1	
01:00	90	1			1				
02:00	86	1			1				
03:00	84				1				
04:00	83				1				
05:00	81				1				
06:00	79				1				
07:00	77				1				
08:00	80				1				
09:00	85	1			1				
10:00	91	1			1				
11:00	96	1			1				
12:00	99	1			1				
13:00	101	1			1				
14:00	103	1			1				
15:00	103	1			1				
16:00	103	1			1				
17:00	100	1			1				
18:00	98	1			1				
19:00	96	1			1				
20:00	98	1			1				
21:00	105	1			1				
22:00	109	1			1				
23:00	106	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 27 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Σάββατο, 27 Ιουνίου 2026	00:00	99	1		1	
01:00	91	1			1				
02:00	85	1			1				
03:00	83	1							
04:00	83	1							
05:00	82	1							
06:00	82	1							
07:00	83	1							
08:00	87	1			1				
09:00	94	1			1				
10:00	98	1			1				
11:00	101	1			1				
12:00	103	1			1				
13:00	104	1			1				
14:00	104	1			1				
15:00	103	1			1				
16:00	103	1			1				
17:00	101	1			1				
18:00	100	1			1				
19:00	98	1			1				
20:00	101	1			1				
21:00	107	1			1				
22:00	110	1			1				
23:00	107	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 28 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Κυριακή, 28 Ιουνίου 2026	00:00	94	1		1	
01:00	89	1			1				
02:00	87	1			1				
03:00	88	1			1				
04:00	88	1			1				
05:00	87	1			1				
06:00	83	1							
07:00	81	1							
08:00	81	1							
09:00	87	1			1				
10:00	93	1			1				
11:00	99	1			1				
12:00	103	1			1				
13:00	102	1			1				
14:00	100	1			1				
15:00	98	1			1				
16:00	97	1			1				
17:00	96	1			1				
18:00	93	1			1				
19:00	92	1			1				
20:00	93	1			1				
21:00	99	1			1				
22:00	102	1			1				
23:00	100	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 29 Ιουνίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Δευτέρα, 29 Ιουνίου 2026	00:00	95	1		1	
01:00	88	1			1				
02:00	84				1				
03:00	82				1				
04:00	81				1				
05:00	79				1				
06:00	77				1				
07:00	78				1				
08:00	85				1				
09:00	93	1			1				
10:00	99	1			1				
11:00	103	1			1				
12:00	107	1			1				
13:00	103	1			1				
14:00	102	1			1				
15:00	99	1			1				
16:00	98	1			1				
17:00	98	1			1				
18:00	99	1			1				
19:00	99	1			1				
20:00	98	1			1				
21:00	101	1			1				
22:00	103	1			1				
23:00	100	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Τρίτη, 30 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Τρίτη, 30 Ιουνίου 2026	00:00	99	1		1	
01:00	91	1			1				
02:00	86	1			1				
03:00	85	1			1				
04:00	85	1			1				
05:00	85	1			1				
06:00	84	1			1				
07:00	85	1			1				
08:00	88	1			1				
09:00	94	1			1				
10:00	101	1			1				
11:00	107	1			1				
12:00	110	1			1				
13:00	111	1			1				
14:00	110	1			1				
15:00	107	1			1				
16:00	105	1			1				
17:00	103	1			1				
18:00	101	1			1				
19:00	99	1			1				
20:00	102	1			1				
21:00	108	1			1				
22:00	112	1			1				
23:00	109	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης