

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 2 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Ρ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Τρίτη, 2 Ιουνίου 2026	00:00	1,259			1	1	
01:00		1,180			1	1		
02:00		1,124			1	1		
03:00		1,139			1	1		
04:00		1,136			1	1		
05:00		1,134	1			1		
06:00		1,142	1			1		
07:00		1,229			1	1		
08:00		1,370			1	1		
09:00		1,449			1	1		
10:00		1,499			1	1		
11:00		1,481			1	1		
12:00		1,505		1	1	1		
13:00		1,478		1	1	1		
14:00		1,438			1	1		
15:00		1,385			1	1		
16:00		1,475			1	1		
17:00		1,533			1	1		
18:00		1,584			1	1		
19:00		1,737			1	1		
20:00		1,784			1	1		
21:00		1,778			1	1		
22:00		1,653			1	1		
23:00		1,486			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 3 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Τετάρτη, 3 Ιουνίου 2026	00:00	1,308			1	1	
01:00		1,235			1	1		
02:00		1,182			1	1		
03:00		1,188			1	1		
04:00		1,188			1	1		
05:00		1,188	1		1			
06:00		1,227	1		1			
07:00		1,362	1		1			
08:00		1,452	1		1	1		
09:00		1,568		1	1	1		
10:00		1,544		1	1	1		
11:00		1,510		1	1	1		
12:00		1,510		1	1	1		
13:00		1,514		1	1	1		
14:00		1,527			1	1		
15:00		1,464			1	1		
16:00		1,446			1	1		
17:00		1,489			1	1		
18:00		1,577			1	1		
19:00		1,740			1	1		
20:00	1,815			1	1			
21:00	1,848			1	1			
22:00	1,646			1	1			
23:00	1,445			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 4 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Πέμπτη, 4 Ιουνίου 2026	00:00	1,305			1	1	
01:00		1,216			1	1		
02:00		1,196			1	1		
03:00		1,184			1	1		
04:00		1,143			1	1		
05:00		1,150			1	1		
06:00		1,197			1	1		
07:00		1,333			1	1		
08:00		1,469			1	1		
09:00		1,557		1	1	1		
10:00		1,542		1	1	1		
11:00		1,459		1	1	1		
12:00		1,518		1	1	1		
13:00		1,526		1	1	1		
14:00		1,556			1	1		
15:00		1,509			1	1		
16:00		1,521			1	1		
17:00		1,493			1	1		
18:00		1,530			1	1		
19:00		1,623			1	1		
20:00		1,670			1	1		
21:00		1,818			1	1		
22:00		1,662			1	1		
23:00		1,369			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 5 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,160			1	1			
02:00	1,111			1	1			
03:00	0,997			1	1			
04:00	1,016			1	1			
05:00	1,047			1	1			
06:00	1,066			1	1			
07:00	1,191			1	1			
08:00	1,271		1	1	1			
09:00	1,507		1	1	1			
10:00	1,567		1	1	1			
11:00	1,586		1	1	1			
12:00	1,611		1	1	1			
13:00	1,592		1	1	1			
14:00	1,558			1	1			
15:00	1,437			1	1			
16:00	1,469			1	1			
17:00	1,541			1	1			
18:00	1,624			1	1			
19:00	1,696			1	1			
20:00	1,732			1	1			
21:00	1,765			1	1			
22:00	1,624			1	1			
23:00	1,502			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 6 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Σάββατο, 6 Ιουνίου 2026	00:00	1,303			1	1	
01:00		1,219			1	1		
02:00		1,176			1	1		
03:00		1,163			1	1		
04:00		1,173			1	1		
05:00		1,174			1	1		
06:00		1,108			1	1		
07:00		1,230			1	1		
08:00		1,349			1	1		
09:00		1,403			1	1		
10:00		1,495			1	1		
11:00		1,513			1	1		
12:00		1,516			1	1		
13:00		1,544			1	1		
14:00		1,551			1	1		
15:00		1,505			1	1		
16:00		1,497			1	1		
17:00		1,519			1	1		
18:00		1,618			1	1		
19:00		1,686			1	1		
20:00		1,769			1	1		
21:00		1,829			1	1		
22:00		1,719			1	1		
23:00		1,548			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 7 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Κυριακή, 7 Ιουνίου 2026	00:00	1,353			1	1	
01:00		1,244			1	1		
02:00		1,134			1	1		
03:00		1,065			1	1		
04:00		1,041			1	1		
05:00		1,063			1	1		
06:00		1,084			1	1		
07:00		1,143			1	1		
08:00		1,294		1	1	1		
09:00		1,390		1	1	1		
10:00		1,525		1	1	1		
11:00		1,535		1	1	1		
12:00		1,572		1	1	1		
13:00		1,566		1	1	1		
14:00		1,568			1	1		
15:00		1,460			1	1		
16:00		1,416			1	1		
17:00		1,526			1	1		
18:00		1,632			1	1		
19:00		1,752			1	1		
20:00		1,771			1	1		
21:00		1,865			1	1		
22:00		1,714			1	1		
23:00		1,543			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 8 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Δευτέρα, 8 Ιουνίου 2026	00:00	1,395			1	1	
01:00		1,292			1	1		
02:00		1,269			1	1		
03:00		1,212			1	1		
04:00		1,208			1	1		
05:00		1,244			1	1		
06:00		1,300			1	1		
07:00		1,328			1	1		
08:00		1,434			1	1		
09:00		1,531		1	1	1		
10:00		1,463		1	1	1		
11:00		1,465		1	1	1		
12:00		1,528		1	1	1		
13:00		1,513		1	1	1		
14:00		1,480			1	1		
15:00		1,498			1	1		
16:00		1,473			1	1		
17:00		1,523			1	1		
18:00		1,644			1	1		
19:00		1,833			1	1		
20:00		1,848			1	1		
21:00		1,818			1	1		
22:00		1,695			1	1		
23:00		1,516			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση