

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 9 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 9 Ιουνίου 2026	00:00	1,360			1	1		
	01:00	1,272			1	1		
	02:00	1,236			1	1		
	03:00	1,189			1	1		
	04:00	1,204			1	1		
	05:00	1,226			1	1		
	06:00	1,305			1	1		
	07:00	1,375			1	1		
	08:00	1,445			1	1		
	09:00	1,530		1	1	1		
	10:00	1,489		1	1	1		
	11:00	1,420		1	1	1		
	12:00	1,542		1	1	1		
	13:00	1,629		1	1	1		
	14:00	1,530		1	1	1		
	15:00	1,439			1	1		
	16:00	1,418			1	1		
	17:00	1,474			1	1		
	18:00	1,589			1	1		
	19:00	1,701			1	1		
	20:00	1,816			1	1		
	21:00	1,835			1	1		
	22:00	1,702			1	1		
	23:00	1,487			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 10 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,249			1	1			
02:00	1,204			1	1			
03:00	1,176			1	1			
04:00	1,105			1	1			
05:00	1,081			1	1			
06:00	1,122			1	1			
07:00	1,206			1	1			
08:00	1,346			1	1			
09:00	1,418		1	1	1			
10:00	1,393		1	1	1			
11:00	1,391		1	1	1			
12:00	1,533		1	1	1			
13:00	1,530		1	1	1			
14:00	1,506			1	1			
15:00	1,407			1	1			
16:00	1,432			1	1			
17:00	1,532			1	1			
18:00	1,627			1	1			
19:00	1,764			1	1			
20:00	1,783			1	1			
21:00	1,807			1	1			
22:00	1,666			1	1			
23:00	1,526			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 11 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,286			1	1			
02:00	1,220			1	1			
03:00	1,180			1	1			
04:00	1,177			1	1			
05:00	1,134			1	1			
06:00	1,121			1	1			
07:00	1,218			1	1			
08:00	1,388		1	1	1			
09:00	1,481		1	1	1			
10:00	1,519		1	1	1			
11:00	1,532		1	1	1			
12:00	1,628		1	1	1			
13:00	1,588		1	1	1			
14:00	1,562			1	1			
15:00	1,463			1	1			
16:00	1,473			1	1			
17:00	1,507			1	1			
18:00	1,569			1	1			
19:00	1,711			1	1			
20:00	1,777			1	1			
21:00	1,839			1	1			
22:00	1,687			1	1			
23:00	1,535			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 12 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,271		1		1			
02:00	1,215		1		1			
03:00	1,179		1		1			
04:00	1,171		1		1			
05:00	1,137		1		1			
06:00	1,097		1		1			
07:00	1,237		1		1			
08:00	1,413		1		1			
09:00	1,453		1	1	1			
10:00	1,397		1	1	1			
11:00	1,394		1	1	1			
12:00	1,510		1	1	1			
13:00	1,562		1	1	1			
14:00	1,513			1	1			
15:00	1,463			1	1			
16:00	1,571			1	1			
17:00	1,720			1	1			
18:00	1,878			1	1			
19:00	1,861			1	1			
20:00	1,908			1	1			
21:00	1,905			1	1			
22:00	1,815			1	1			
23:00	1,625			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 13 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Σάββατο, 13 Ιουνίου 2026	00:00	1,453			1	1	
01:00		1,328			1	1		
02:00		1,295			1	1		
03:00		1,264			1	1		
04:00		1,248			1	1		
05:00		1,218			1	1		
06:00		1,166			1	1		
07:00		1,277			1	1		
08:00		1,450			1	1		
09:00		1,503			1	1		
10:00		1,432			1	1		
11:00		1,567			1	1		
12:00		1,609			1	1		
13:00		1,593			1	1		
14:00		1,599			1	1		
15:00		1,518			1	1		
16:00		1,507			1	1		
17:00		1,563			1	1		
18:00		1,719			1	1		
19:00		1,714			1	1		
20:00		1,807			1	1		
21:00		1,791			1	1		
22:00		1,633			1	1		
23:00		1,468			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 14 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,310		1	1				
02:00	1,268		1	1				
03:00	1,177		1	1				
04:00	1,153		1	1				
05:00	1,074		1	1				
06:00	1,075		1	1				
07:00	1,174		1	1				
08:00	1,277		1	1				
09:00	1,348		1	1	1			
10:00	1,437		1	1	1			
11:00	1,511		1	1	1			
12:00	1,506		1	1	1			
13:00	1,499			1	1			
14:00	1,467			1	1			
15:00	1,486			1	1			
16:00	1,424			1	1			
17:00	1,448			1	1			
18:00	1,521			1	1			
19:00	1,635			1	1			
20:00	1,723			1	1			
21:00	1,747			1	1			
22:00	1,652			1	1			
23:00	1,480			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 15 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,271			1	1			
02:00	1,191			1	1			
03:00	1,172			1	1			
04:00	1,202			1	1			
05:00	1,201			1	1			
06:00	1,195			1	1			
07:00	1,313			1	1			
08:00	1,467			1	1			
09:00	1,554			1	1			
10:00	1,566			1	1			
11:00	1,525			1	1			
12:00	1,605			1	1			
13:00	1,581			1	1			
14:00	1,529			1	1			
15:00	1,481			1	1			
16:00	1,483			1	1			
17:00	1,605			1	1			
18:00	1,716			1	1			
19:00	1,831			1	1			
20:00	1,800			1	1			
21:00	1,879			1	1			
22:00	1,789			1	1			
23:00	1,602			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση