

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 24 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,429	1			1			
02:00	1,362	1			1			
03:00	1,328	1			1			
04:00	1,307	1			1			
05:00	1,305	1			1			
06:00	1,331	1			1			
07:00	1,381	1			1			
08:00	1,476	1			1			
09:00	1,560	1			1			
10:00	1,625	1			1			
11:00	1,656	1			1			
12:00	1,671	1			1			
13:00	1,672	1			1			
14:00	1,660	1			1			
15:00	1,644	1			1			
16:00	1,655	1			1			
17:00	1,688	1			1			
18:00	1,768	1			1			
19:00	1,882	1	1		1			
20:00	1,987	1	1		1			
21:00	2,024	1	1		1			
22:00	1,928	1	1		1			
23:00	1,763	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 25 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,447	1	1					
02:00	1,381	1	1					
03:00	1,340	1	1					
04:00	1,314	1	1					
05:00	1,310	1	1					
06:00	1,350	1	1					
07:00	1,418	1	1					
08:00	1,511	1	1					
09:00	1,596	1	1					
10:00	1,637	1	1					
11:00	1,663	1	1					
12:00	1,678	1	1					
13:00	1,678	1	1					
14:00	1,658	1	1					
15:00	1,642	1	1					
16:00	1,644	1	1					
17:00	1,678	1	1					
18:00	1,740	1	1					
19:00	1,887	1	1			1		
20:00	1,983	1	1			1		
21:00	2,002	1	1			1		
22:00	1,908	1	1			1		
23:00	1,746	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 26 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,501	1			1			
02:00	1,442	1			1			
03:00	1,398	1			1			
04:00	1,359	1			1			
05:00	1,344	1			1			
06:00	1,367	1			1			
07:00	1,460	1			1			
08:00	1,582	1			1			
09:00	1,683	1			1			
10:00	1,735	1			1			
11:00	1,746	1			1			
12:00	1,748	1			1			
13:00	1,754	1			1			
14:00	1,754	1			1			
15:00	1,749	1			1			
16:00	1,740	1			1			
17:00	1,771	1			1			
18:00	1,855	1	1		1			
19:00	1,966	1	1		1			
20:00	2,044	1	1		1			
21:00	2,016	1	1		1			
22:00	1,902	1	1		1			
23:00	1,741	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 27 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,513	1	1					
02:00	1,451	1	1					
03:00	1,400	1	1					
04:00	1,361	1	1					
05:00	1,373	1	1					
06:00	1,412	1	1					
07:00	1,490	1	1					
08:00	1,612	1	1					
09:00	1,718	1	1					
10:00	1,791	1	1					
11:00	1,796	1	1					
12:00	1,811	1	1					
13:00	1,811	1	1					
14:00	1,804	1	1					
15:00	1,781	1	1					
16:00	1,782	1	1					
17:00	1,816	1	1					
18:00	1,880	1	1					
19:00	1,979	1	1			1		
20:00	2,058	1	1			1		
21:00	2,048	1	1			1		
22:00	1,937	1	1			1		
23:00	1,784	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 28 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,537	1			1			
02:00	1,467	1			1			
03:00	1,416	1			1			
04:00	1,381	1			1			
05:00	1,364	1			1			
06:00	1,390	1			1			
07:00	1,455	1			1			
08:00	1,555	1			1			
09:00	1,660	1			1			
10:00	1,737	1			1			
11:00	1,770	1			1			
12:00	1,774	1			1			
13:00	1,758	1			1			
14:00	1,731	1			1			
15:00	1,695	1			1			
16:00	1,674	1			1			
17:00	1,696	1			1			
18:00	1,777	1			1			
19:00	1,885	1	1		1			
20:00	1,966	1	1		1			
21:00	1,967	1	1		1			
22:00	1,873	1	1		1			
23:00	1,741	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 29 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,520	1	1					
02:00	1,438	1	1					
03:00	1,381	1	1					
04:00	1,340	1	1					
05:00	1,329	1	1					
06:00	1,373	1	1					
07:00	1,460	1	1					
08:00	1,571	1	1					
09:00	1,678	1	1					
10:00	1,743	1	1					
11:00	1,775	1	1					
12:00	1,794	1	1					
13:00	1,789	1	1					
14:00	1,771	1	1					
15:00	1,742	1	1					
16:00	1,737	1	1					
17:00	1,758	1	1					
18:00	1,824	1	1					
19:00	1,925	1	1			1		
20:00	2,012	1	1			1		
21:00	2,029	1	1			1		
22:00	1,929	1	1			1		
23:00	1,792	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 30 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,522	1	1					
02:00	1,460	1	1					
03:00	1,421	1	1					
04:00	1,389	1	1					
05:00	1,379	1	1					
06:00	1,422	1	1					
07:00	1,502	1	1					
08:00	1,604	1	1					
09:00	1,706	1	1					
10:00	1,781	1	1					
11:00	1,828	1	1					
12:00	1,864	1	1					
13:00	1,885	1	1					
14:00	1,892	1	1		1			
15:00	1,881	1	1		1			
16:00	1,866	1	1		1			
17:00	1,864	1	1		1			
18:00	1,907	1	1		1			
19:00	1,987	1	1		1			
20:00	2,067	1	1		1			
21:00	2,066	1	1		1			
22:00	1,974	1	1		1			
23:00	1,815	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση