

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 1 Ιουνίου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 1 Ιουνίου 2026	00:00	35,59	1	1		1	1	1		1		1	
	01:00	33,93	1	1		1	1	1		1		1	
	02:00	32,32	1	1		1	1	1		1		1	
	03:00	31,80	1	1		1	1	1		1		1	
	04:00	31,20	1	1		1	1	1		1		1	
	05:00	30,78	1	1		1	1	1		1		1	
	06:00	32,50	1	1		1	1	1		1		1	
	07:00	36,37	1	1		1	1	1		1		1	
	08:00	39,62	1	1		1	1	1		1		1	
	09:00	43,06	1	1		1	1	1		1		1	2
	10:00	44,33	1	1		1	1	1		1		1	2
	11:00	44,44	1	1		1	1	1		1		1	2
	12:00	45,53	1	1		1	1	1		1	1	1	
	13:00	45,63	1	1		1	1	1		1	1	1	
	14:00	45,42	1	1		1	1	1		1	1	1	
	15:00	43,75	1	1		1	1	1		1	1	1	
	16:00	43,09	1	1		1	1	1		1	1	1	
	17:00	43,48	1	1		1	1	1		1	1	1	
	18:00	44,94	1	1		1	1	1		1	1	1	
	19:00	45,94	1	1		1	1	1		1	1	1	
20:00	46,21	1	1		1	1	1		1	1	1		
21:00	46,83	1	1		1	1	1		1	1	1		
22:00	44,27	1	1		1	1	1		1	1	1		
23:00	40,32	1	1		1	1	1		1	1	1		

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης