

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 2 Ιουνίου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 2 Ιουνίου 2026	00:00	36,78	1	1		1	1	1		1		1	
	01:00	34,98	1	1		1	1	1		1		1	
	02:00	33,56	1	1		1	1	1		1		1	
	03:00	32,05	1	1		1	1	1		1		1	
	04:00	31,71	1	1		1	1	1		1		1	
	05:00	31,17	1	1		1	1	1		1		1	
	06:00	32,19	1	1		1	1	1		1		1	
	07:00	37,30	1	1		1	1	1		1	1	1	
	08:00	41,61	1	1			1	1		1	1	1	
	09:00	43,89	1	1			1	1		1	1	1	
	10:00	44,54	1	1			1	1		1	1	1	
	11:00	44,90	1	1			1	1		1	1	1	
	12:00	45,87	1	1			1	1		1	1	1	
	13:00	46,14	1	1			1	1		1	1	1	
	14:00	45,32	1	1			1	1		1	1	1	
	15:00	44,19	1	1			1	1		1	1	1	
	16:00	44,28	1	1			1	1		1	1	1	
	17:00	44,65	1	1			1	1		1	1	1	
	18:00	45,74	1	1			1	1		1	1	1	
	19:00	46,12	1	1			1	1		1	1	1	
20:00	46,36	1	1			1	1		1	1	1		
21:00	47,18	1	1			1	1		1	1	1		
22:00	45,56	1	1			1	1		1	1	1		
23:00	41,13	1	1			1	1		1	1	1		

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης