

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 3 Ιουνίου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Α Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τετάρτη, 3 Ιουνίου 2026	00:00	37,04	1	1			1	1		1	1	1	
	01:00	34,83	1	1			1	1		1		1	
	02:00	33,83	1	1			1	1		1		1	
	03:00	32,57	1	1			1	1		1		1	
	04:00	31,71	1	1			1	1		1		1	
	05:00	31,90	1	1			1	1		1		1	
	06:00	33,99	1	1			1	1		1		1	
	07:00	38,38	1	1			1	1		1	1	1	
	08:00	41,74	1	1			1	1		1	1	1	
	09:00	44,77	1	1			1	1		1	1	1	
	10:00	46,09	1	1			1	1		1	1	1	
	11:00	46,40	1	1			1	1		1	1	1	
	12:00	46,41	1	1			1	1		1	1	1	
	13:00	46,75	1	1			1	1		1	1	1	
	14:00	46,12	1	1			1	1		1	1	1	
	15:00	45,85	1	1			1	1		1	1	1	
	16:00	45,69	1	1			1	1		1	1	1	
	17:00	45,46	1	1			1	1		1	1	1	
	18:00	46,29	1	1			1	1		1	1	1	
19:00	47,37	1	1			1	1		1	1	1	2	
20:00	48,58	1	1			1	1		1	1	1	2	
21:00	48,16	1	1			1	1		1	1	1		
22:00	45,95	1	1			1	1		1	1	1		
23:00	41,73	1	1			1	1		1	1	1		

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης