

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 8 Ιουνίου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 8 Ιουνίου 2026	00:00	38,59	1	1			1	1		1	1	1	
	01:00	35,94	1	1			1	1		1	1	1	
	02:00	34,74	1	1			1	1		1	1	1	
	03:00	34,08	1	1			1	1		1	1	1	
	04:00	33,55	1	1			1	1		1	1	1	
	05:00	33,64	1	1			1	1		1	1	1	
	06:00	34,93	1	1			1	1		1	1	1	
	07:00	39,57	1	1			1	1		1	1	1	
	08:00	43,86	1	1			1	1		1	1	1	
	09:00	46,71	1	1			1	1		1	1	1	
	10:00	47,97	1	1			1	1		1	1	1	
	11:00	48,77	1	1			1	1		1	1	1	
	12:00	49,86	1	1			1	1		1	1	1	
	13:00	50,83	1	1			1	1		1	1	1	
	14:00	50,32	1	1			1	1		1	1	1	
	15:00	49,50	1	1			1	1		1	1	1	
	16:00	48,17	1	1			1	1		1	1	1	
	17:00	47,84	1	1			1	1		1	1	1	
	18:00	48,97	1	1			1	1		1	1	1	
	19:00	49,22	1	1			1	1		1	1	1	
	20:00	49,18	1	1			1	1		1	1	1	
	21:00	49,56	1	1			1	1		1	1	1	
	22:00	47,97	1	1			1	1		1	1	1	
	23:00	44,04	1	1			1	1		1	1	1	

Επτά φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης