

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 13 Ιουνίου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000	
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Σάββατο, 13 Ιουνίου 2026	00:00	40,21	1	1			1	1		1	1	1	
	01:00	37,72	1	1			1	1		1	1	1	
	02:00	36,09	1	1			1	1		1	1	1	
	03:00	35,01	1	1			1	1		1	1	1	
	04:00	34,41	1	1			1	1		1	1	1	
	05:00	34,57	1	1			1	1		1	1	1	
	06:00	35,28	1	1			1	1		1	1	1	
	07:00	39,66	1	1			1	1		1	1	1	
	08:00	40,25	1	1			1	1		1	1	1	
	09:00	45,94	1	1			1	1		1	1	1	
	10:00	47,75	1	1			1			1	1	1	3
	11:00	47,89	1	1			1			1	1	1	3
	12:00	49,07	1	1			1			1	1	1	4
	13:00	48,72	1	1			1			1	1	1	4
	14:00	48,55	1	1			1			1	1	1	4
	15:00	48,25	1	1			1			1	1	1	3
	16:00	47,93	1	1			1			1	1	1	3
	17:00	48,05	1	1			1			1	1	1	1
	18:00	48,69	1	1			1			1	1	1	1
	19:00	48,62	1	1			1	1		1	1	1	2
	20:00	48,46	1	1			1	1		1	1	1	
	21:00	49,88	1	1			1	1		1	1	1	
	22:00	47,51	1	1			1	1		1	1	1	
23:00	43,88	1	1			1	1		1	1	1		

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης