

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 15 Ιουνίου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000	
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
	Δευτέρα, 15 Ιουνίου 2026	00:00	38,95	1	1			1	1		1	1	1
01:00		36,42	1	1			1	1		1	1	1	
02:00		34,97	1	1			1	1		1	1	1	
03:00		33,89	1	1			1	1		1	1	1	
04:00		33,22	1	1			1	1		1	1	1	
05:00		33,49	1	1			1	1		1	1	1	
06:00		33,78	1	1			1	1		1	1	1	
07:00		38,04	1	1			1	1		1	1	1	
08:00		42,08	1	1			1	1		1	1	1	
09:00		45,43	1	1			1	1		1	1	1	
10:00		46,63	1	1			1	1		1	1	1	
11:00		47,13	1	1			1	1		1	1	1	
12:00		48,39	1	1			1	1		1	1	1	
13:00		48,91	1	1			1	1		1	1	1	
14:00		48,44	1	1			1	1		1	1	1	
15:00		47,42	1	1			1	1		1	1	1	
16:00		47,22	1	1			1	1		1	1	1	
17:00		48,04	1	1			1	1		1	1	1	
18:00		48,94	1	1			1	1		1	1	1	
19:00		48,60	1	1			1	1		1	1	1	
20:00		48,41	1	1			1	1		1	1	1	
21:00		48,27	1	1			1	1		1	1	1	
22:00		46,96	1	1			1	1		1	1	1	
23:00		42,76	1	1			1	1		1	1	1	

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης