

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 21 Ιουνίου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000	
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
	Κυριακή, 21 Ιουνίου 2026	00:00	40,59	1	1			1	1		1	1	1
01:00		37,78	1	1			1	1		1	1	1	
02:00		36,06	1	1			1	1		1	1	1	
03:00		35,68	1	1			1	1		1	1	1	
04:00		34,64	1	1			1	1		1	1	1	
05:00		33,94	1	1			1	1		1	1	1	
06:00		34,38	1	1			1	1		1	1	1	
07:00		38,80	1	1			1	1		1	1	1	
08:00		42,66	1	1			1	1		1	1	1	
09:00		45,16	1	1			1	1		1	1	1	
10:00		47,17	1	1			1	1		1	1	1	
11:00		47,96	1	1			1	1		1	1	1	
12:00		48,89	1	1			1	1		1	1	1	
13:00		49,38	1	1			1	1		1	1	1	
14:00		49,34	1	1			1	1		1	1	1	
15:00		48,22	1	1			1	1		1	1	1	
16:00		47,16	1	1			1	1		1	1	1	
17:00		47,59	1	1			1	1		1	1	1	
18:00	48,77	1	1			1	1		1	1	1		
19:00	49,17	1	1			1	1		1	1	1		
20:00	48,54	1	1			1	1		1	1	1		
21:00	49,13	1	1			1	1		1	1	1		
22:00	48,48	1	1			1	1		1	1	1		
23:00	44,62	1	1			1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης