

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας										Παρασκευή, 26 Ιουνίου 2026											
Αποδιδόμενη Ισχύς (MW)						7,500	10,000	10,000	10,000	13,500	13,500	10,885	9,142	9,142	28,000	1,400	1,800	1,800	5,500	5,500	5,500	8,250		
Α	Σ	Ρ	Ε	Σ	Τ	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)	
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6
Παρασκευή, 26 Ιουνίου 2026																								
	00:00	64,89	59,57	5,16	0,15		1	1	1	1	1		1						1	1		1	16,10	16,10
	01:00	60,59	54,13	6,45	0,01		1	1	1	1	1								1	1		1	16,10	16,10
	02:00	57,75	51,01	6,74	0,01		1	1	1	1	1								1			1	16,10	16,10
	03:00	55,72	48,66	7,06	0,01		1	1	1	1	1								1			1	15,57	15,84
	04:00	54,49	47,49	7,00	0,01		1	1	1	1	1								1			1	14,47	14,61
	05:00	55,33	48,64	6,68	0,01		1	1	1	1	1								1			1	15,32	15,45
	06:00	57,86	51,47	6,19	0,21		1	1	1	1	1								1			1	15,98	16,10
	07:00	65,85	60,09	5,55	0,21		1	1	1	1	1								1		1	1	16,10	16,10
	08:00	68,96	64,30	4,45	0,21		1	1	1	1	1				1				1		1	1	16,10	16,10
	09:00	72,43	67,71	4,51	0,21		1	1	1	1	1				1				1		1	1	16,10	16,10
	10:00	75,45	72,01	3,24	0,20		1	1	1	1	1				1				1		1	1	16,10	16,10
	11:00	77,66	75,96	1,50	0,21		1	1	1	1	1		1		1				1		1	1	16,10	16,10
	12:00	76,48	75,16	1,11	0,21		1	1	1	1	1		1		1				1		1	1	16,10	16,10
	13:00	81,56	79,56	1,79	0,21		1	1	1	1	1		1		1				1		1	1	16,10	16,10
	14:00	80,84	77,97	2,66	0,21		1	1	1	1	1		1		1				1		1	1	16,10	16,10
	15:00	78,85	75,62	3,02	0,21		1	1	1	1	1		1		1				1		1	1	16,10	16,10
	16:00	80,36	78,16	1,99	0,21		1	1	1	1	1		1		1				1		1	1	16,10	16,10
	17:00	85,28	83,37	1,71	0,21		1	1	1	1	1		1		1				1	1	1	1	16,10	16,10
	18:00	90,85	89,89	0,95	0,01		1	1	1	1	1		1		1				1	1	1	1	16,10	16,10
	19:00	91,28	90,23	0,97	0,08		1	1	1	1	1		1		1				1	1	1	1	16,10	16,10
	20:00	88,31	86,77	1,37	0,17		1	1	1	1	1		1		1				1	1	1	1	16,10	16,10
	21:00	84,99	84,16	0,71	0,12		1	1	1	1	1		1		1				1	1	1	1	16,10	16,10
	22:00	78,57	77,66	0,75	0,15		1	1	1	1	1		1		1				1	1	1	1	16,10	16,10
23:00	72,72	70,92	1,62	0,18		1	1	1	1	1		1		1				1	1	1	1	16,10	16,10	

Το διάστημα 8:00-12:00 πραγματοποιήθηκαν προγραμματισμένες εργασίες στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση