

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας										Κυριακή, 28 Ιουνίου 2026												
Αποδιδόμενη Ισχύς (MW)						7,500	10,000	10,000	10,000	13,500	13,500	10,885	9,142	9,142	28,000	1,400	1,800	1,800	5,500	5,500	5,500	8,250			
Α	Ρ	Ε	Τ	Η	Μ	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)		
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6	
Κυριακή, 28 Ιουνίου 2026																									
	00:00	72,47	68,02	4,45	0,01		1	1	1	1	1		1						1	1	1	1	16,10	16,10	
	01:00	68,26	63,56	4,69	0,01		1	1	1	1	1		1						1	1	1	1	16,10	16,10	
	02:00	65,18	60,40	4,78	0,01		1	1	1	1	1								1	1	1	1	16,10	16,10	
	03:00	62,44	58,37	4,07	0,01		1	1	1	1	1								1	1	1	1	15,97	16,10	
	04:00	60,53	56,69	3,84	0,00		1	1	1	1	1								1	1	1	1	14,72	14,85	
	05:00	60,40	56,59	3,80	0,01		1	1	1	1	1								1	1	1	1	14,53	14,71	
	06:00	61,53	57,97	3,55	0,00		1	1	1	1	1								1	1	1	1	15,34	15,85	
	07:00	68,47	64,77	3,69	0,01			1	1	1	1	1				1			1	1	1	1	16,10	16,10	
	08:00	73,47	70,40	3,04	0,03				1	1	1	1		1			1			1	1	1	1	16,10	16,10
	09:00	76,75	73,74	2,96	0,06				1	1	1	1		1			1			1	1	1	1	16,10	16,10
	10:00	77,91	75,95	1,89	0,08		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	11:00	78,35	76,65	1,53	0,17		1	1	1	1	1	1		1			1			1	1	1	1	16,08	16,10
	12:00	79,79	77,06	2,59	0,15		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	13:00	81,55	77,94	3,61	0,00		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	14:00	80,71	76,15	4,56	0,00		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	15:00	79,22	72,83	6,23	0,16		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	16:00	80,86	74,88	5,88	0,10		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	17:00	84,69	78,88	5,81	0,01		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	18:00	90,73	87,07	3,66	0,01		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	19:00	91,62	88,57	3,03	0,02		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	20:00	88,49	85,03	3,46	0,01		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	21:00	87,18	82,98	4,16	0,04		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
	22:00	82,08	77,08	4,99	0,01		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10
23:00	76,96	71,96	4,97	0,02		1	1	1	1	1	1		1			1			1	1	1	1	16,10	16,10	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση