

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 23 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,453	9,234	10,150	10,150	1,000	1,000	
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x15)
	Τρίτη, 23 Ιουνίου 2026	00:00	40,79	1	1			1	1		1	1	1	
01:00		37,98	1	1			1	1		1	1	1		
02:00		35,71	1	1			1	1		1	1	1		
03:00		34,78	1	1			1	1		1	1	1		
04:00		34,03	1	1			1	1		1	1	1		
05:00		35,14	1	1			1	1		1	1	1		
06:00		36,09	1	1			1	1		1	1	1		
07:00		39,75	1	1			1	1		1	1	1		
08:00		39,54	1	1			1	1		1	1	1		
09:00		42,71	1	1			1	1		1	1	1		
10:00		50,07	1	1			1	1		1	1	1	1	
11:00		51,01	1	1			1	1		1	1	1	2	
12:00		51,51	1	1			1	1		1	1	1	3	
13:00		52,57	1	1			1	1		1	1	1	4	
14:00		52,46	1	1			1	1		1	1	1	3	
15:00		51,72	1	1			1	1		1	1	1	2	
16:00		51,07	1	1			1	1		1	1	1	2	
17:00		51,28	1	1			1	1		1	1	1	2	
18:00		52,00	1	1			1	1		1	1	1	2	
19:00		51,61	1	1			1	1		1	1	1	2	
20:00	51,28	1	1			1	1		1	1	1	2		
21:00	50,76	1	1			1	1		1	1	1	1		
22:00	49,13	1	1			1	1		1	1	1			
23:00	45,71	1	1			1	1		1	1	1			

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης