

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 17 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ρ Ε Π	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	1,113			1			1		
02:00	1,073			1			1		
03:00	0,985			1			1		
04:00	0,946			1			1		
05:00	0,990			1			1		
06:00	0,997			1			1		
07:00	1,146			1			1		
08:00	1,279			1			1		
09:00	1,374			1			1		
10:00	1,447			1			1		
11:00	1,464			1			1		
12:00	1,504						1	1	
13:00	1,497						1	1	
14:00	1,508						1	1	
15:00	1,485						1	1	
16:00	1,545						1	1	
17:00	1,566						1	1	
18:00	1,635						1	1	
19:00	1,708						1	1	
20:00	1,712						1	1	
21:00	1,666						1	1	
22:00	1,585						1	1	
23:00	1,413						1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 18 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ρ Α Ρ Ε Τ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	1,132		1					1	
02:00	1,079		1					1	
03:00	1,046		1					1	
04:00	1,006		1					1	
05:00	1,051		1					1	
06:00	1,066		1					1	
07:00	1,165		1					1	
08:00	1,267		1					1	
09:00	1,337		1					1	
10:00	1,445		1					1	
11:00	1,465		1					1	
12:00	1,416		1					1	
13:00	1,443		1					1	
14:00	1,473		1					1	
15:00	1,478		1					1	
16:00	1,485		1					1	
17:00	1,538		1					1	
18:00	1,606		1					1	
19:00	1,716		1					1	
20:00	1,665		1					1	
21:00	1,687		1					1	
22:00	1,560		1					1	
23:00	1,394		1					1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 19 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	1,138					1		1	
02:00	1,103					1		1	
03:00	1,037					1		1	
04:00	0,999					1		1	
05:00	1,005					1		1	
06:00	1,026					1		1	
07:00	1,152					1		1	
08:00	1,250					1		1	
09:00	1,402					1		1	
10:00	1,426					1		1	
11:00	1,421					1		1	
12:00	1,438					1		1	
13:00	1,456					1		1	
14:00	1,480					1		1	
15:00	1,482					1		1	
16:00	1,528					1		1	
17:00	1,568					1	1	1	
18:00	1,657					1	1	1	
19:00	1,696					1	1	1	
20:00	1,719					1	1	1	
21:00	1,733					1	1	1	
22:00	1,601					1	1	1	
23:00	1,427					1		1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 20 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	1,158					1		1	
02:00	1,085					1		1	
03:00	1,043					1		1	
04:00	1,019					1		1	
05:00	1,051					1		1	
06:00	1,068					1		1	
07:00	1,180					1		1	
08:00	1,312					1		1	
09:00	1,415					1		1	
10:00	1,460					1		1	
11:00	1,467					1		1	
12:00	1,446					1		1	
13:00	1,485					1		1	
14:00	1,527					1		1	
15:00	1,504					1		1	
16:00	1,512					1		1	
17:00	1,560					1		1	
18:00	1,653					1	1	1	
19:00	1,793					1	1	1	
20:00	1,755					1	1	1	
21:00	1,738					1	1	1	
22:00	1,651					1	1	1	
23:00	1,497					1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 21 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ρ Ε Τ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	1,194					1		1	
02:00	1,134					1		1	
03:00	1,094					1		1	
04:00	1,067					1		1	
05:00	1,099					1		1	
06:00	1,104					1		1	
07:00	1,202					1		1	
08:00	1,281					1		1	
09:00	1,431					1		1	
10:00	1,476					1		1	
11:00	1,535					1		1	
12:00	1,522			1				1	
13:00	1,546			1				1	
14:00	1,557			1				1	
15:00	1,524			1				1	
16:00	1,495			1				1	
17:00	1,557			1				1	
18:00	1,675			1		1		1	
19:00	1,750			1		1		1	
20:00	1,751			1		1		1	
21:00	1,724			1		1		1	
22:00	1,593			1		1		1	
23:00	1,450			1		1		1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 22 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ρ Α Ρ Ε Τ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	1,177			1				1	
02:00	1,117			1				1	
03:00	1,081			1				1	
04:00	1,014			1				1	
05:00	1,047			1				1	
06:00	1,061			1				1	
07:00	1,215			1				1	
08:00	1,352			1				1	
09:00	1,426			1				1	
10:00	1,460			1				1	
11:00	1,489			1				1	
12:00	1,467						1	1	
13:00	1,540						1	1	
14:00	1,570						1	1	
15:00	1,509						1	1	
16:00	1,543						1	1	
17:00	1,602						1	1	
18:00	1,668						1	1	
19:00	1,799						1	1	
20:00	1,798						1	1	
21:00	1,780						1	1	
22:00	1,671						1	1	
23:00	1,510						1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 23 Ιουνίου 2026					
Αποδιδόμενη Ισχύς (MW)		0,400	1,050	1,050	1,050	0,950	0,950	0,950	
Η Ε Ρ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	1,178					1		1	
02:00	1,123					1		1	
03:00	1,046					1		1	
04:00	1,031					1		1	
05:00	1,074					1		1	
06:00	1,105					1		1	
07:00	1,241					1		1	
08:00	1,324					1		1	
09:00	1,432					1		1	
10:00	1,482					1		1	
11:00	1,517					1		1	
12:00	1,522					1		1	
13:00	1,563					1		1	
14:00	1,535					1	1	1	
15:00	1,560					1	1	1	
16:00	1,539					1	1	1	
17:00	1,575					1	1	1	
18:00	1,651					1	1	1	
19:00	1,769					1	1	1	
20:00	1,826					1	1	1	
21:00	1,765					1	1	1	
22:00	1,576					1	1	1	
23:00	1,466					1		1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση