



ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 26 Μαΐου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Τρίτη, 26 Μαΐου 2026	00:00	1,070	1				1	
01:00	1,012	1					1				
02:00	0,959	1					1				
03:00	0,946	1					1				
04:00	0,955	1					1				
05:00	0,945	1					1				
06:00	0,998	1					1				
07:00	1,205	1					1				
08:00	1,547	1					1				
09:00	1,769	1					1				
10:00	1,801	1					1				
11:00	1,987	1					1				1
12:00	2,059	1					1				1
13:00	2,080	1					1				1
14:00	2,028	1					1				1
15:00	1,871	1					1				1
16:00	1,790	1					1				1
17:00	1,855	1					1				1
18:00	2,005	1					1				1
19:00	2,056	1					1				1
20:00	2,116	1					1				1
21:00	2,012	1					1				1
22:00	1,465	1					1				
23:00	1,261	1					1				

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 27 Μαΐου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ	Θ	Ε	Σ	Η							
	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 27 Μαΐου 2026	00:00	1,116	1				1				
	01:00	1,027	1				1				
	02:00	0,974	1				1				
	03:00	0,982	1				1				
	04:00	0,972	1				1				
	05:00	0,982	1				1				
	06:00	1,010	1								1
	07:00	1,209	1								1
	08:00	1,405	1								1
	09:00	1,926	1				1				1
	10:00	2,027	1				1				1
	11:00	2,044	1				1				1
	12:00	2,107	1				1				1
	13:00	2,125	1				1				1
	14:00	2,040	1				1				1
	15:00	1,917	1				1				1
	16:00	1,851	1				1				1
	17:00	1,872	1				1				1
	18:00	2,048	1				1				1
	19:00	2,094	1				1				1
	20:00	2,119	1				1				1
	21:00	1,954	1				1				1
	22:00	1,694	1				1				1
	23:00	1,271	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 28 Μαΐου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Πέμπτη, 28 Μαΐου 2026	00:00	1,117	1				1	
01:00	1,027	1					1				
02:00	0,997	1					1				
03:00	0,994	1					1				
04:00	1,000	1					1				
05:00	0,994	1					1				
06:00	1,031	1					1				
07:00	1,237	1					1				
08:00	1,623	1					1				
09:00	1,796	1					1				
10:00	2,005	1					1				1
11:00	2,095	1					1				1
12:00	2,222	1					1				1
13:00	2,241	1					1				1
14:00	2,157	1					1				1
15:00	1,966	1					1				1
16:00	1,873	1					1				1
17:00	1,911	1					1				1
18:00	2,030	1					1				1
19:00	2,109	1					1				1
20:00	2,147	1					1				1
21:00	2,129	1					1				1
22:00	1,747	1					1				1
23:00	1,297	1					1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 29 Μαΐου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Παρασκευή, 29 Μαΐου 2026	00:00	1,145	1				1	
01:00	1,062	1					1				
02:00	1,012	1					1				
03:00	1,011	1					1				
04:00	0,986	1					1				
05:00	1,002	1					1				
06:00	1,061	1					1				
07:00	1,245	1					1				
08:00	1,603	1					1				
09:00	1,912	1					1				1
10:00	1,934	1					1				1
11:00	2,059	1					1				1
12:00	2,083	1					1				1
13:00	1,997	1					1				1
14:00	1,975	1					1				1
15:00	1,846	1					1				1
16:00	1,772	1					1				1
17:00	1,810	1					1				1
18:00	1,929	1					1				1
19:00	1,885	1					1				1
20:00	1,934	1					1				1
21:00	2,008	1					1				1
22:00	1,822	1					1				1
23:00	1,373	1					1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 30 Μαΐου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Σάββατο, 30 Μαΐου 2026	00:00	1,196	1				1	
01:00	1,087	1					1				
02:00	1,021	1					1				
03:00	1,016	1					1				
04:00	0,999	1					1				
05:00	1,001	1					1				
06:00	1,032	1					1				
07:00	1,213	1					1				
08:00	1,617	1					1				
09:00	1,813	1					1				1
10:00	1,861	1					1				1
11:00	1,881	1					1				1
12:00	1,968	1					1				1
13:00	2,007	1					1				1
14:00	1,996	1					1				1
15:00	1,855	1					1				1
16:00	1,751	1					1				1
17:00	1,761	1					1				1
18:00	1,937	1					1				1
19:00	1,976	1					1				1
20:00	1,992	1					1				1
21:00	1,987	1					1				1
22:00	1,846	1					1				1
23:00	1,350	1					1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 31 Μαΐου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Ε Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Κυριακή, 31 Μαΐου 2026	00:00	1,189	1				1	
01:00	1,076	1					1				
02:00	1,019	1					1				
03:00	1,009						1		1		
04:00	0,995						1		1		
05:00	0,984						1		1		
06:00	1,050						1		1		
07:00	1,226						1		1		
08:00	1,592						1		1		1
09:00	1,721						1				1
10:00	1,753	1						1			1
11:00	1,883	1						1			1
12:00	1,977	1						1			1
13:00	1,976	1						1			1
14:00	1,728	1						1			1
15:00	1,601	1						1			1
16:00	1,501	1						1			1
17:00	1,716	1						1			
18:00	1,908	1						1			1
19:00	1,950	1						1			1
20:00	1,941	1						1			1
21:00	1,944	1						1			1
22:00	1,835	1						1			1
23:00	1,359	1						1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 1 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Δευτέρα, 1 Ιουνίου 2026	00:00	1,179	1				1	
01:00	1,086	1					1				
02:00	1,030	1					1				
03:00	1,019	1					1				
04:00	1,017	1					1				
05:00	0,996	1					1				
06:00	1,041	1					1				
07:00	1,170	1					1				
08:00	1,416	1					1				
09:00	1,737	1					1				1
10:00	1,805	1					1				1
11:00	1,853	1					1				1
12:00	1,954	1					1				1
13:00	2,037	1					1				1
14:00	1,982	1					1				1
15:00	1,826	1					1				1
16:00	1,729	1					1				1
17:00	1,794	1					1				1
18:00	1,973	1					1				1
19:00	2,024	1					1				1
20:00	1,972	1					1				1
21:00	1,982	1					1				1
22:00	1,724	1					1				1
23:00	1,348	1					1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης