

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Τετάρτη, 29 Ιουλίου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 29 Ιουλίου 2026	00:00	110	1		1				
	01:00	104	1		1				
	02:00	99	1		1				
	03:00	96	1		1				
	04:00	95	1		1				
	05:00	93	1		1				
	06:00	90	1		1				
	07:00	88	1		1				
	08:00	91	1		1				
	09:00	98	1		1				
	10:00	106	1		1				
	11:00	112	1		1				
	12:00	116	1		1				
	13:00	119	1		1				
	14:00	122	1		1				
	15:00	125	1		1				
	16:00	126	1		1				
	17:00	123	1		1				
	18:00	119	1		1				
	19:00	114	1		1				
	20:00	115	1		1				
	21:00	120	1		1				
	22:00	123	1		1				
	23:00	121	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Πέμπτη, 30 Ιουλίου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 30 Ιουλίου 2026	00:00	115	1		1				
	01:00	108	1		1				
	02:00	103	1		1				
	03:00	101	1		1				
	04:00	101	1		1				
	05:00	100	1		1				
	06:00	97	1		1				
	07:00	95	1		1				
	08:00	97	1		1				
	09:00	104	1		1				
	10:00	112	1		1				
	11:00	117	1		1				
	12:00	120	1		1				
	13:00	120	1		1				
	14:00	120	1		1				
	15:00	121	1		1				
	16:00	121	1		1				
	17:00	119	1		1				
	18:00	115	1		1				
	19:00	110	1		1				
	20:00	110	1		1				
	21:00	118	1		1				
	22:00	123	1		1				
	23:00	120	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Παρασκευή, 31 Ιουλίου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 31 Ιουλίου 2026	00:00	115	1		1				
	01:00	105	1		1				
	02:00	99	1		1				
	03:00	96	1		1				
	04:00	95	1		1				
	05:00	93	1		1				
	06:00	90	1		1				
	07:00	88	1		1				
	08:00	89	1		1				
	09:00	96	1		1				
	10:00	103	1		1				
	11:00	108	1		1				
	12:00	113	1		1				
	13:00	115	1		1				
	14:00	119	1		1				
	15:00	122	1		1				
	16:00	123	1		1				
	17:00	122	1		1				
	18:00	119	1		1				
	19:00	113	1		1				
	20:00	112	1		1				
	21:00	120	1		1				
	22:00	125	1		1				
	23:00	122	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Σάββατο, 1 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 1 Αυγούστου 2026	00:00	116	1		1				
	01:00	108	1		1				
	02:00	102	1		1				
	03:00	99	1		1				
	04:00	98	1		1				
	05:00	98	1		1				
	06:00	99	1		1				
	07:00	101	1		1				
	08:00	106	1		1				
	09:00	111	1		1				
	10:00	117	1		1				
	11:00	120	1		1				
	12:00	121	1		1				
	13:00	121	1		1				
	14:00	118	1		1				
	15:00	118	1		1				
	16:00	120	1		1				
	17:00	121	1		1				
	18:00	121	1		1				
	19:00	116	1		1				
	20:00	121	1		1				
	21:00	127	1		1				
	22:00	129	1		1				
	23:00	125	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Κυριακή, 2 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 2 Αυγούστου 2026	00:00	119	1		1				
	01:00	114	1		1				
	02:00	110	1		1				
	03:00	108	1		1				
	04:00	106	1		1				
	05:00	103	1		1				
	06:00	99	1		1				
	07:00	96	1		1				
	08:00	97	1		1				
	09:00	102	1		1				
	10:00	109	1		1				
	11:00	115	1		1				
	12:00	118	1		1				
	13:00	120	1		1				
	14:00	122	1		1				
	15:00	122	1		1				
	16:00	122	1		1				
	17:00	122	1		1				
	18:00	119	1		1				
	19:00	115	1		1				
	20:00	115	1		1				
	21:00	120	1		1				
	22:00	123	1		1				
	23:00	123	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Δευτέρα, 3 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 3 Αυγούστου 2026	00:00	113	1		1				
	01:00	107	1		1				
	02:00	103	1		1				
	03:00	101	1		1				
	04:00	100	1		1				
	05:00	99	1		1				
	06:00	97	1		1				
	07:00	96	1		1				
	08:00	101	1		1				
	09:00	107	1		1				
	10:00	113	1		1				
	11:00	118	1		1				
	12:00	120	1		1				
	13:00	121	1		1				
	14:00	122	1		1				
	15:00	120	1		1				
	16:00	119	1		1				
	17:00	117	1		1				
	18:00	117	1		1				
	19:00	111	1		1				
	20:00	112	1		1				
	21:00	115	1		1				
	22:00	119	1		1				
	23:00	118	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Τρίτη, 4 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 4 Αυγούστου 2026	00:00	112	1		1				
	01:00	105	1		1				
	02:00	101	1		1				
	03:00	100	1		1				
	04:00	99	1		1				
	05:00	98	1		1				
	06:00	97	1		1				
	07:00	96	1		1				
	08:00	98	1		1				
	09:00	104	1		1				
	10:00	112	1		1				
	11:00	119	1		1				
	12:00	123	1		1				
	13:00	124	1		1				
	14:00	124	1		1				
	15:00	122	1		1				
	16:00	121	1		1				
	17:00	118	1		1				
	18:00	116	1		1				
	19:00	114	1		1				
	20:00	117	1		1				
	21:00	121	1		1				
	22:00	125	1		1				
	23:00	123	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης