

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 30 Ιουνίου 2026						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Τρίτη, 30 Ιουνίου 2026	00:00	1,580		1	1	1			
	01:00	1,462			1	1			
	02:00	1,356			1	1			
	03:00	1,310			1	1			
	04:00	1,326			1	1			
	05:00	1,306			1	1			
	06:00	1,300			1	1			
	07:00	1,433			1	1			
	08:00	1,567			1	1			
	09:00	1,753			1	1			
	10:00	1,759			1	1			
	11:00	1,829			1	1			
	12:00	1,786			1	1			
	13:00	1,896			1	1			
	14:00	1,964			1	1			
	15:00	1,890			1	1			
	16:00	1,912			1	1			
	17:00	2,023			1	1			
	18:00	2,109		1	1	1			
	19:00	2,154		1	1	1			
	20:00	2,155		1	1	1			
	21:00	2,226		1	1	1			
	22:00	2,079		1	1	1			
	23:00	1,900		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 1 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Τετάρτη, 1 Ιουλίου 2026	00:00	1,748		1	1	1			
	01:00	1,629			1	1			
	02:00	1,533			1	1			
	03:00	1,496			1	1			
	04:00	1,479			1	1			
	05:00	1,460			1	1			
	06:00	1,497			1	1			
	07:00	1,594			1	1			
	08:00	1,702			1	1			
	09:00	1,765			1	1			
	10:00	1,784			1	1			
	11:00	1,879			1	1			
	12:00	1,936			1	1			
	13:00	1,894			1	1			
	14:00	1,892			1	1			
	15:00	1,838			1	1			
	16:00	1,859			1	1			
	17:00	1,955			1	1			
	18:00	1,998			1	1			
	19:00	2,123		1	1	1			
	20:00	2,189		1	1	1			
	21:00	2,218		1	1	1			
	22:00	2,163		1	1	1			
	23:00	1,992		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 2 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Πέμπτη, 2 Ιουλίου 2026	00:00	1,772		1	1	1			
	01:00	1,669			1	1			
	02:00	1,583			1	1			
	03:00	1,497			1	1			
	04:00	1,502			1	1			
	05:00	1,468			1	1			
	06:00	1,483			1	1			
	07:00	1,642			1	1			
	08:00	1,823			1	1			
	09:00	1,891			1	1			
	10:00	1,946			1	1			
	11:00	2,004		1	1	1			
	12:00	2,022		1	1	1			
	13:00	2,088		1	1	1			
	14:00	2,079		1	1	1			
	15:00	1,960		1	1	1			
	16:00	1,926		1	1	1			
	17:00	2,056		1	1	1			
	18:00	2,075		1	1	1			
	19:00	2,152		1	1	1			
	20:00	2,339		1	1	1			
	21:00	2,373		1	1	1			
	22:00	2,256		1	1	1			
	23:00	2,080		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 3 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x2)
Παρασκευή, 3 Ιουλίου 2026	00:00	1,845		1	1	1			
	01:00	1,708		1		1			
	02:00	1,615		1		1			
	03:00	1,575		1		1			
	04:00	1,553		1		1			
	05:00	1,532		1		1			
	06:00	1,532		1		1			
	07:00	1,640		1		1			
	08:00	1,776		1		1			
	09:00	1,960		1	1	1			
	10:00	1,996		1	1	1			
	11:00	1,944		1	1	1			
	12:00	1,960		1	1	1			
	13:00	2,096		1	1	1			
	14:00	2,083		1	1	1			
	15:00	1,958		1	1	1			
	16:00	2,021		1	1	1			
	17:00	2,074		1	1	1			
	18:00	2,139		1	1	1			
	19:00	2,240		1	1	1			
	20:00	2,222		1	1	1			
	21:00	2,282		1	1	1			
	22:00	2,294		1	1	1			
	23:00	2,040		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 4 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Σάββατο, 4 Ιουλίου 2026	00:00	1,867		1	1	1			
	01:00	1,720			1	1			
	02:00	1,578			1	1			
	03:00	1,550			1	1			
	04:00	1,567			1	1			
	05:00	1,531			1	1			
	06:00	1,527			1	1			
	07:00	1,674			1	1			
	08:00	1,874			1	1			
	09:00	2,006		1	1	1			
	10:00	1,958		1	1	1			
	11:00	1,953		1	1	1			
	12:00	1,994		1	1	1			
	13:00	2,082		1	1	1			
	14:00	2,073		1	1	1			
	15:00	2,048		1	1	1			
	16:00	2,022		1	1	1			
	17:00	2,029		1	1	1			
	18:00	2,199		1	1	1			
	19:00	2,288		1	1	1			
	20:00	2,339		1	1	1			
	21:00	2,389		1	1	1			
	22:00	2,288		1	1	1			
	23:00	2,132		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 5 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460	1,100
Η Ε Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x2)
Κυριακή, 5 Ιουλίου 2026	00:00	1,909		1	1	1			
	01:00	1,761			1	1			
	02:00	1,697			1	1			
	03:00	1,596			1	1			
	04:00	1,584			1	1			
	05:00	1,561			1	1			
	06:00	1,557			1	1			
	07:00	1,617			1	1			
	08:00	1,740			1	1			
	09:00	1,899			1	1			
	10:00	1,950			1	1			
	11:00	1,941		1	1	1			
	12:00	1,959		1	1	1			
	13:00	1,975		1	1	1			
	14:00	1,955		1	1	1			
	15:00	1,906		1	1	1			
	16:00	1,867		1	1	1			
	17:00	1,940		1	1	1			
	18:00	2,030		1	1	1			
	19:00	2,200		1	1	1			
	20:00	2,273		1	1	1			
	21:00	2,306		1	1	1			
	22:00	2,128		1	1	1			
	23:00	1,956		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 6 Ιουλίου 2026						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Δευτέρα, 6 Ιουλίου 2026	00:00	1,764		1	1	1			
	01:00	1,638		1	1				
	02:00	1,526		1	1				
	03:00	1,480		1	1				
	04:00	1,483		1	1				
	05:00	1,487		1	1				
	06:00	1,451		1	1				
	07:00	1,583		1	1				
	08:00	1,532		1	1				
	09:00	1,747		1	1				
	10:00	1,923		1	1				
	11:00	1,957		1	1	1			
	12:00	1,923		1	1	1			
	13:00	1,941		1	1	1			
	14:00	1,955		1	1	1			
	15:00	1,841		1	1	1			
	16:00	1,847		1	1	1			
	17:00	1,932		1	1	1			
	18:00	2,115		1	1	1			
	19:00	2,202		1	1	1			
	20:00	2,210		1	1	1			
	21:00	2,293		1	1	1			
	22:00	2,134		1	1	1			
	23:00	1,918		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση