

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 4 Ιουλίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	0,900
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Σάββατο, 4 Ιουλίου 2026	00:00	47,31		1	1		1	1		1	1	1	1	
	01:00	44,26		1	1		1	1		1	1	1		
	02:00	41,93		1	1		1	1		1	1	1		
	03:00	40,25		1	1		1	1		1	1	1		
	04:00	39,51		1	1		1	1		1	1	1		
	05:00	39,77		1	1		1	1		1	1	1		
	06:00	40,19		1	1		1	1		1	1	1		
	07:00	41,85	1	1	1		1	1		1	1	1		
	08:00	44,83	1	1	1		1	1		1	1	1		1
	09:00	47,66	1	1	1		1	1		1	1	1		5
	10:00	49,32	1	1	1		1	1		1	1	1		6
	11:00	48,70	1	1	1		1	1		1	1	1		7
	12:00	50,00	1	1	1		1	1		1	1	1		7
	13:00	51,70	1	1	1	1	1	1		1	1	1		7
	14:00	52,57	1	1	1	1	1	1		1	1	1		8
	15:00	51,93	1	1	1	1	1	1		1	1	1		8
	16:00	50,96	1	1	1	1	1	1		1	1	1		8
	17:00	51,71	1	1	1	1	1	1		1	1	1		8
	18:00	51,96	1	1	1	1	1	1		1	1	1		8
	19:00	50,38	1	1	1	1	1	1		1	1	1		8
	20:00	48,63	1	1	1	1	1	1		1	1	1		8
	21:00	48,42	1	1	1	1	1	1		1	1	1		8
	22:00	46,88	1	1	1	1	1	1		1	1	1		8
	23:00	45,50	1	1	1	1	1	1		1	1	1		5

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης