

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 5 Ιουλίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	0,900
Η Ρ Α Κ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Κυριακή, 5 Ιουλίου 2026	00:00	47,55	1	1	1	1	1	1		1	1	1		
	01:00	44,16	1	1	1	1	1	1			1	1		
	02:00	41,81	1	1	1	1	1	1			1	1		
	03:00	40,34	1	1	1	1	1	1			1	1		
	04:00	39,37	1	1	1	1	1	1			1	1		
	05:00	38,65	1	1	1	1	1	1			1	1		
	06:00	39,70	1	1	1	1	1	1			1	1		
	07:00	40,56	1	1	1	1	1	1			1	1		2
	08:00	42,41	1	1	1	1		1			1	1		5
	09:00	43,71	1	1	1	1		1			1	1		7
	10:00	43,41	1	1	1	1		1			1	1		7
	11:00	43,75	1	1	1	1	1	1			1	1		6
	12:00	45,27	1	1	1	1	1	1			1	1		6
	13:00	46,50	1	1	1	1	1	1			1	1		7
	14:00	47,33	1	1	1	1	1	1			1	1		8
	15:00	46,33	1	1	1	1	1	1			1	1		9
	16:00	46,39	1	1	1	1	1	1			1	1		9
	17:00	46,70	1	1	1	1	1	1			1	1		9
	18:00	47,79	1	1	1	1	1	1			1	1		9
	19:00	47,20	1	1	1	1	1	1			1	1		8
	20:00	46,32	1	1	1	1	1	1			1	1		8
	21:00	46,41	1	1	1	1	1	1			1	1		8
	22:00	44,51	1	1	1	1	1	1			1	1		8
	23:00	43,07	1	1	1	1	1	1			1	1	1	5

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης