

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 6 Ιουλίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Δευτέρα, 6 Ιουλίου 2026	00:00	45,43	1	1	1	1	1	1			1	1	1	
	01:00	41,90	1	1	1	1	1	1			1	1		
	02:00	40,29	1	1	1	1	1	1			1	1		
	03:00	39,03	1	1	1	1	1	1			1	1		
	04:00	38,03	1	1	1	1	1	1			1	1		
	05:00	37,67	1	1	1	1	1	1			1	1		
	06:00	38,69	1	1	1	1	1	1			1	1		
	07:00	38,51	1	1	1	1	1	1			1	1		
	08:00	41,42	1	1	1	1	1	1			1	1	1	2
	09:00	50,25	1	1	1	1	1	1			1	1	1	10
	10:00	52,99	1	1	1	1	1	1			1	1		14
	11:00	53,63	1	1	1	1	1	1			1	1		14
	12:00	55,04	1	1	1	1	1	1			1	1		16
	13:00	55,81	1	1	1	1	1	1			1	1		17
	14:00	55,73	1	1	1	1	1	1			1	1		17
	15:00	54,92	1	1	1	1	1	1			1	1		17
	16:00	54,21	1	1	1	1	1	1			1	1		17
	17:00	54,61	1	1	1	1	1	1			1	1		17
	18:00	55,67	1	1	1	1	1	1			1	1		17
	19:00	54,77	1	1	1	1	1	1			1	1		17
	20:00	53,76	1	1	1	1	1	1			1	1		17
	21:00	53,46	1	1	1	1	1	1			1	1		17
	22:00	52,32	1	1	1	1	1	1			1	1		17
	23:00	48,86	1	1	1	1	1	1			1	1	1	11

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης