

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 10 Ιουλίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Θ Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Παρασκευή, 10 Ιουλίου 2026	00:00	44,42	1	1	1		1	1			1	1		6
	01:00	41,46	1	1	1		1	1			1	1		
	02:00	39,54	1	1	1		1	1			1	1		
	03:00	37,78	1	1	1		1	1			1	1		
	04:00	36,42	1	1	1		1	1			1	1		
	05:00	36,34	1	1	1		1	1			1	1		
	06:00	37,60	1	1	1		1	1			1	1		
	07:00	42,06	1	1	1		1	1			1	1		4
	08:00	46,99	1	1	1		1	1			1	1		9
	09:00	51,54	1	1	1		1	1			1	1		14
	10:00	53,41	1	1	1		1	1			1	1		15
	11:00	54,75	1	1	1	1	1	1			1	1		15
	12:00	56,58	1	1	1	1	1	1			1	1		15
	13:00	57,70	1	1	1	1	1	1			1	1		16
	14:00	57,55	1	1	1	1	1	1			1	1		17
	15:00	55,98	1	1	1	1	1	1			1	1		16
	16:00	55,39	1	1	1	1	1	1			1	1		17
	17:00	56,07	1	1	1	1	1	1			1	1		17
	18:00	56,43	1	1	1	1	1	1			1	1		17
	19:00	55,63	1	1	1	1	1	1			1	1		17
	20:00	54,20	1	1	1	1	1	1			1	1		17
	21:00	54,69	1	1	1	1	1	1			1	1		16
	22:00	53,36	1	1	1	1	1	1			1	1		16
	23:00	49,21	1	1	1	1	1	1			1	1		12

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης