

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 22 Ιουλίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Τετάρτη, 22 Ιουλίου 2026	00:00	47,29	1		1	1	1	1		1	1	1		
	01:00	48,03	1		1	1	1	1		1	1	1		
	02:00	47,17	1		1	1	1	1		1	1	1		
	03:00	45,87	1		1	1	1	1		1	1	1		
	04:00	44,61	1		1	1	1	1		1	1	1		
	05:00	43,35	1		1	1	1	1		1	1	1		
	06:00	44,15	1		1	1	1	1		1	1	1		
	07:00	45,98	1		1	1	1	1		1	1	1		
	08:00	48,49	1		1	1		1		1	1	1		4
	09:00	50,22	1		1	1		1		1	1	1		6
	10:00	51,65	1		1	1	1	1		1	1	1		8
	11:00	52,41	1		1	1	1	1		1	1	1		8
	12:00	53,27	1		1	1	1	1		1	1	1		8
	13:00	55,05	1		1	1	1	1		1	1	1		8
	14:00	55,33	1		1	1	1	1		1	1	1		8
	15:00	55,07	1		1	1	1	1		1	1	1		8
	16:00	54,72	1		1	1	1	1		1	1	1		7
	17:00	54,35	1		1	1	1	1		1	1	1		7
	18:00	53,95	1		1	1	1	1		1	1	1		7
	19:00	53,62	1		1	1	1	1		1	1	1		7
	20:00	52,71	1		1	1	1	1		1	1	1		7
	21:00	53,29	1		1	1	1	1		1	1	1		7
	22:00	51,87	1		1	1	1	1		1	1	1		7
	23:00	47,62	1		1	1	1	1		1	1	1		5

Τέσσερα φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης