

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 23 Ιουλίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Πέμπτη, 23 Ιουλίου 2026	00:00	55,55	1		1	1	1	1		1	1	1		11
	01:00	51,57	1		1	1	1	1		1	1	1	2	4
	02:00	48,35	1		1	1	1	1		1	1	1	1	
	03:00	46,46	1		1	1	1	1		1	1	1		
	04:00	45,30	1		1	1	1	1		1	1	1		
	05:00	44,98	1		1	1	1	1		1	1	1		
	06:00	44,78	1		1	1	1	1		1	1	1		
	07:00	49,01	1		1	1	1	1		1	1	1		3
	08:00	54,29	1		1	1	1	1		1	1	1		10
	09:00	58,56	1		1	1	1	1		1	1	1		13
	10:00	61,06	1		1	1	1	1		1	1	1		14
	11:00	62,82	1		1	1	1	1		1	1	1		16
	12:00	64,59	1		1	1	1	1		1	1	1		18
	13:00	65,23	1		1	1	1	1		1	1	1		19
	14:00	64,91	1		1	1	1	1		1	1	1		19
	15:00	63,96	1		1	1	1	1		1	1	1		19
	16:00	63,07	1		1	1	1	1		1	1	1		19
	17:00	62,56	1		1	1	1	1		1	1	1		19
	18:00	62,40	1		1	1	1	1		1	1	1		19
	19:00	61,18	1		1	1	1	1		1	1	1		19
	20:00	59,90	1		1	1	1	1		1	1	1		19
	21:00	59,50	1		1	1	1	1		1	1	1		19
	22:00	57,26	1		1	1	1	1		1	1	1		18
	23:00	53,55	1		1	1	1	1		1	1	1		14

Τέσσερα φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης