

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 30 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	0,900
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Τρίτη, 30 Ιουνίου 2026	00:00	44,02	1	1	1	1	1			1	1	1		
	01:00	40,83	1	1	1	1	1			1	1	1		
	02:00	38,80	1	1	1	1	1			1	1	1		
	03:00	37,52	1	1	1	1	1			1	1	1		
	04:00	36,78	1	1	1	1	1			1	1	1		
	05:00	36,59	1	1	1	1	1			1	1	1		
	06:00	37,31	1	1	1	1	1			1	1	1		
	07:00	42,34	1	1	1	1	1			1	1	1		
	08:00	46,73	1	1	1	1	1			1	1	1		
	09:00	49,98	1	1	1	1	1			1	1	1		
	10:00	53,04	1	1	1	1	1			1	1	1	3	
	11:00	54,33	1	1	1	1	1	1		1	1	1	3	
	12:00	56,61	1	1	1	1	1	1		1	1	1	2	
	13:00	57,15	1	1	1	1	1	1		1	1	1	3	
	14:00	56,43	1	1	1	1	1	1		1	1	1	3	
	15:00	56,05	1	1	1	1	1	1		1	1	1	3	
	16:00	55,13	1	1	1	1	1	1		1	1	1	3	
	17:00	55,85	1	1	1	1	1	1		1	1	1	3	
	18:00	56,40	1	1	1	1	1	1		1	1	1	3	
	19:00	55,33	1	1	1	1	1	1		1	1	1	3	
	20:00	54,67	1	1	1	1	1	1		1	1	1	2	
	21:00	54,81	1	1	1	1	1	1		1	1	1	2	
	22:00	53,08	1	1	1	1	1	1		1	1	1	1	
	23:00	49,30	1	1	1	1	1	1		1	1	1		

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης