

ΗΣ ΡΟΔΟΥ		Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																		Friday, July 3, 2026								
Αποδιδόμενη Ισχύς (MW)		18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	14.90	14.90	1.00	17.10	17.10	17.10	17.10	17.10	17.10	17.10								
ΤΕ (MW)		14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	3.00	3.00	1.00	6.00	6.00	6.00	6.00	6.00	6.00	6.00								
ΣΥΣΤΗΜΑ	Χρονική στιγμή	Πραγματικό Μέσο Γραμμά Φορτία (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φωτοβολταϊκή Παραγωγή (MW)	ΑΗΣ ΣΟΡΩΝΗΣ								ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (MW)	Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)			
						DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	AEP 7	AEP 8	ΦΩΡΤΑ ΗΣ	DIESEL 1	DIESEL 2	DIESEL 3						DIESEL 4	DIESEL 5	DIESEL 6
Friday, July 3, 2026	00:00	137.92	101.40	36.52	0.00		1	1				1			1			1	1	1	1	1	79.10	48.55	41.38	56%	22,170	
	01:00	129.05	91.48	37.57	0.00		1	1				1			1			1	1	1	1	1	54.82	48.33	38.71	63%	21,536	
	02:00	123.10	87.88	35.22	0.00		1	1				1			1			1	1	1	1	1	58.42	46.59	36.93	60%	20,860	
	03:00	119.14	83.50	35.63	0.00		1	1				1			1			1	1	1	1	1	45.70	44.64	35.74	65%	20,734	
	04:00	117.67	83.30	34.37	0.00		1	1				1			1			1	1	1	1	1	45.90	44.60	35.30	64%	20,695	
	05:00	119.72	87.04	32.68	0.00		1	1				1			1			1	1	1	1	1	42.16	46.12	35.92	67%	21,407	
	06:00	126.06	92.69	32.57	0.79		1	1				1			1			1	1	1	1	1	53.61	47.61	37.58	63%	21,833	
	07:00	144.08	115.25	24.88	3.95		1	1				1			1			1	1	1	1	1	48.15	48.54	42.04	71%	25,218	
	08:00	162.52	136.26	17.25	9.01		1	1				1			1			1	1	1	1	1	44.24	48.55	46.05	75%	28,162	
	09:00	176.70	142.14	20.80	13.77	1	1	1				1	1		1			1	1	1	1	1	89.26	48.55	48.88	61%	36,179	
	10:00	186.25	144.48	24.23	17.54	1	1	1				1	1		1			1	1	1	1	1	86.92	48.55	50.61	62%	36,649	
	11:00	190.58	140.68	29.77	20.13	1	1	1				1	1		1			1	1	1	1	1	90.72	48.55	51.14	61%	35,874	
	12:00	193.34	142.66	29.11	21.57	1	1	1				1	1		1			1	1	1	1	1	88.74	48.55	51.53	62%	36,279	
	13:00	200.96	155.29	23.89	21.77	1	1	1				1	1		1			1	1	1	1	1	93.21	48.55	53.76	62%	38,074	
	14:00	198.85	161.86	16.07	20.92	1	1	1				1	1		1			1	1	1	1	1	69.54	48.55	53.38	70%	40,048	
	15:00	192.51	156.97	16.54	19.01	1	1	1				1	1		1			1	1	1	1	1	74.43	48.55	52.05	68%	39,116	
	16:00	192.95	156.10	20.95	15.89	1	1	1				1	1		1			1	1	1	1	1	75.30	48.55	53.12	67%	38,949	
	17:00	195.71	155.04	29.22	11.45	1	1	1				1	1		1			1	1	1	1	1	76.36	48.55	55.28	67%	38,743	
	18:00	198.93	161.07	31.83	6.03	1	1	1				1	1		1			1	1	1	1	1	70.33	48.55	57.87	70%	39,898	
	19:00	196.58	160.84	34.04	1.70	1	1	1				1	1		1			1	1	1	1	1	70.56	48.55	58.46	70%	39,856	
	20:00	189.19	156.37	32.75	0.08	1	1	1				1	1		1			1	1	1	1	1	75.03	48.55	56.73	68%	39,001	
	21:00	181.73	149.53	32.19	0.00	1	1	1				1	1		1			1	1	1	1	1	81.87	48.55	54.52	65%	37,662	
	22:00	169.13	140.80	28.33	0.00	1	1	1				1	1		1			1	1	1	1	1	90.60	48.55	50.74	61%	35,898	
	23:00	157.50	126.41	31.09	0.00	1	1	1				1	1		1			1	1	1	1	1	72.09	48.55	47.25	64%	26,165	
4000.17 MWh																									ΑΩΛ: 23.58		761,006 €	

Παρατηρήσεις:

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης