

ΗΣ ΡΟΔΟΥ				Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																				Saturday, July 4, 2026						
Αποδιδόμενη Ισχύς (MW)						18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	14.90	14.90	1.00	17.10	17.10	17.10	17.10	17.10	17.10	17.10						
ΤΕ (MW)						14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	3.00	3.00	1.00	6.00	6.00	6.00	6.00	6.00	6.00	6.00						
ΣΑΡΑΝΤΗ	Χρονική στιγμή	Πραγματικό Μέσο θριατό φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φωτοβολταϊκή Παραγωγή (MW)	ΑΗΣ ΣΟΡΩΝΗΣ								ΘΗΣ Ν. ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (MW)	Εντολή περιορισμού των Αιολικών πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής παραγωγής (MW)	Μέση φόρτιση μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)					
						DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	AEP 7	AEP 8	ΦΟΡΤΑ ΗΖ	DIESEL 1	DIESEL 2	DIESEL 3						DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7	
Saturday, July 4, 2026	00:00	146.31	113.24	33.07	0.00		1	1				1						1	1		1	1	1	1	67.26	48.55	43.89	63%	24,260	
	01:00	137.54	99.09	38.45	0.00		1	1				1						1	1		1	1		1	64.31	48.55	41.26	61%	22,311	
	02:00	131.12	92.38	38.74	0.00		1	1				1						1	1		1			1	53.92	48.55	39.34	63%	21,704	
	03:00	126.56	89.69	36.87	0.00		1	1				1						1	1		1			1	56.61	48.55	37.97	61%	21,202	
	04:00	122.66	87.72	34.94	0.00		1	1				1						1			1			1	41.48	48.21	36.80	68%	21,533	
	05:00	124.67	91.64	33.03	0.00		1	1				1						1	1		1			1	54.66	45.96	37.40	63%	21,636	
	06:00	129.43	97.51	31.12	0.81		1	1				1						1	1		1			1	48.79	47.56	38.59	67%	22,644	
	07:00	146.30	119.85	22.58	3.87	1	1	1				1						1	1		1			1	44.45	48.55	42.73	73%	26,152	
	08:00	163.21	134.54	19.81	8.86	1	1	1				1						1	1		1			1	46.86	48.55	46.31	74%	28,050	
	09:00	177.85	149.77	14.42	13.66	1	1	1				1						1	1		1	1		1	48.73	48.55	49.26	75%	30,013	
	10:00	183.25	150.75	15.08	17.43	1	1	1				1						1	1		1	1		1	47.75	48.55	49.75	76%	30,096	
	11:00	183.31	145.54	17.85	19.92	1	1	1				1						1	1		1	1		1	52.96	48.55	49.02	73%	29,278	
	12:00	188.16	141.19	25.80	21.18	1	1	1				1						1	1		1	1		1	57.31	48.55	50.10	71%	28,585	
	13:00	194.38	147.06	25.94	21.38	1	1	1				1						1	1		1	1		1	51.44	48.55	51.90	74%	29,518	
	14:00	195.44	148.65	26.35	20.45	1	1	1				1						1	1		1	1		1	49.85	48.55	52.50	75%	29,768	
	15:00	192.95	143.43	30.93	18.59	1	1	1				1						1	1		1	1		1	55.07	48.55	52.31	72%	28,942	
	16:00	193.73	147.40	30.90	15.42	1	1	1				1						1	1		1	1		1	51.10	48.55	53.49	74%	29,572	
	17:00	195.47	154.21	30.30	10.96	1	1	1				1						5	1	1	1	1	1	1	1	61.39	48.55	55.35	70%	30,862
	18:00	196.55	160.69	30.04	5.81	1	1	1				1						5	1	1	1	1	1	1	1	54.91	48.55	57.22	73%	31,827
	19:00	193.65	161.03	30.97	1.66	1	1	1				1						5	1	1	1	1	1	1	1	54.57	48.55	57.60	73%	31,881
	20:00	187.61	156.46	31.08	0.07	1	1	1				1						5	1	1	1	1	1	1	1	59.14	48.55	56.26	71%	31,153
	21:00	181.63	150.84	30.79	0.00	1	1	1				1						4	1	1	1	1	1	1	1	64.76	48.55	54.49	69%	30,138
	22:00	172.74	142.73	30.01	0.00	1	1	1				1							1	1	1	1	1	1	1	72.87	48.55	51.82	66%	28,398
	23:00	163.41	138.87	24.54	0.00	1	1	1				1							1	1		1	1	1	1	59.63	48.55	49.02	70%	28,213
		4027.93 MWh																					ΑΔΛ: 23.77		657,736 €					

Παρατηρήσεις:

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης