

ΗΣ ΡΟΔΟΥ				Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																	Sunday, July 5, 2026									
Αποδιδόμενη Ισχύς (MW)						18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	14.90	14.90	1.00	17.10	17.10	17.10	17.10	17.10	17.10	17.10						
TE (MW)						14.00	14.00	14.00	5.00	5.00	5.00	5.00	6.60	3.00	3.00	1.00	6.80	6.80	6.80	6.80	6.80	6.80	6.80							
ΣΕΡΤΗ	Χρονική στιγμή	Πραγματικό Μέσο Όριο φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φωτοβολταϊκή Παραγωγή (MW)	ΑΗΣ ΣΟΡΩΝΗΣ								ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (MW)	Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)	Μέση φόρτιση μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)					
						DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	AEP 7	AEP 8	ΦΟΡΤΙΑ ΗΣ	DIESEL 1	DIESEL 2	DIESEL 3						DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7	
Sunday, July 5, 2026	00:00	152.62	127.63	24.99	0.00		1	1				1			1			1	1	1	1					52.87	48.55	45.79	71%	26,690
	01:00	143.81	118.98	24.84	0.00		1	1				1			1			1	1	1	1					61.52	48.55	43.14	66%	25,243
	02:00	136.21	111.96	24.25	0.00		1	1				1			1			1	1	1	1					51.44	48.51	40.86	69%	24,584
	03:00	130.86	106.35	24.52	0.00		1	1				1			1			1	1	1	1					57.05	47.91	39.26	65%	23,607
	04:00	127.38	102.67	24.71	0.00		1	1				1			1			1	1					1		43.63	47.83	38.21	70%	23,566
	05:00	126.92	107.06	19.86	0.00		1	1				1			1			1	1							39.24	46.42	38.08	73%	24,332
	06:00	128.91	114.09	14.09	0.73		1	1				1			1			1	1		1					49.31	46.49	38.45	70%	25,020
	07:00	143.31	130.27	9.42	3.63	1	1	1				1			1			1	1	1	1					68.23	48.54	41.91	66%	26,947
	08:00	157.40	142.97	6.03	8.40	1	1	1				1			1			1	1	1	1					55.53	48.55	44.70	72%	28,869
	09:00	166.79	148.50	5.27	13.02	1	1	1				1			1			1	1	1	1					50.00	48.55	46.13	75%	29,744
	10:00	172.42	151.93	3.96	16.53	1	1	1				1			1			1	1	1	1					46.57	48.55	46.77	77%	30,281
	11:00	173.49	152.19	2.30	19.00	1	1	1				1			1		3	1	1	1	1					46.31	48.55	46.35	76%	30,688
	12:00	177.09	153.91	2.93	20.25	1	1	1				1			1		5	1	1		1	1	1	1		44.59	48.55	47.05	76%	31,201
	13:00	180.49	154.36	5.86	20.28	1	1	1				1			1		4	1	1		1	1	1	1		44.14	48.55	48.06	76%	31,152
	14:00	179.41	148.59	11.24	19.58	1	1	1				1			1		4	1	1		1	1	1	1		49.91	48.55	47.95	73%	30,233
	15:00	176.66	147.90	11.21	17.55	1	1	1				1			1		5	1	1		1	1	1	1		50.60	48.55	47.73	73%	30,236
	16:00	177.13	152.25	10.21	14.67	1	1	1				1			1		5	1	1		1	1	1	1		46.25	48.55	48.74	75%	30,936
	17:00	180.09	160.49	9.18	10.42	1	1	1				1	1		1		4	1	1		1	1	1	1		70.91	48.55	50.90	68%	40,152
	18:00	185.21	172.60	7.09	5.52	1	1	1				1	1		1		7	1	1		1	1	1	1		58.80	48.55	53.91	72%	42,721
	19:00	184.98	175.36	8.01	1.62	1	1	1				1	1		1		12	1	1		1	1	1	1		56.04	48.55	55.01	72%	43,714
	20:00	181.27	175.57	5.62	0.07	1	1	1				1	1		1		19	1	1		1	1	1	1		55.83	48.55	54.36	72%	43,848
	21:00	178.14	173.96	4.19	0.00	1	1	1				1	1		1		7	1	1		1	1	1	1		57.44	48.55	53.44	73%	42,974
	22:00	172.11	168.49	3.62	0.00	1	1	1				1	1		1			1	1	1	1	1	1	1		80.01	48.55	51.63	68%	40,608
	23:00	161.13	156.52	4.61	0.00	1	1	1		1		1			1			1	1	1	1	1	1	1		81.08	48.55	48.34	66%	37,020
		3893.86 MWh																							ΑΩΔ: 23.74		764,366 €			

Παρατηρήσεις:

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης