

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 24 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τετάρτη, 24 Ιουνίου 2026	00:00	1,759	1						1	1		
	01:00	1,615	1						1	1		
	02:00	1,476	1						1			
	03:00	1,455	1						1			
	04:00	1,396	1						1			
	05:00	1,429	1						1			
	06:00	1,533	1						1			
	07:00	1,530	1						1			
	08:00	1,689	1						1			
	09:00	1,760	1						1		1	
	10:00	1,882	1						1		1	
	11:00	1,882	1						1		1	
	12:00	1,972	1						1		1	
	13:00	2,025	1						1		1	
	14:00	2,079	1						1		1	
	15:00	2,006	1						1		1	
	16:00	1,941	1						1		1	
	17:00	1,987	1						1		1	
	18:00	2,119	1						1		1	
	19:00	2,178	1						1		1	
	20:00	2,201	1						1		1	
	21:00	2,227	1						1		1	
	22:00	2,088	1						1		1	
	23:00	1,945	1						1		1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 25 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Πέμπτη, 25 Ιουνίου 2026	00:00	1,727	1						1		1	
	01:00	1,597	1						1		1	
	02:00	1,484	1						1			
	03:00	1,437	1						1			
	04:00	1,410	1						1			
	05:00	1,389	1						1			
	06:00	1,449	1						1			
	07:00	1,505	1						1			
	08:00	1,598	1						1		1	
	09:00	1,755	1						1		1	
	10:00	1,849	1						1		1	
	11:00	1,938	1						1		1	
	12:00	2,099	1						1		1	
	13:00	2,143	1						1		1	
	14:00	2,212	1						1		1	
	15:00	2,152	1						1		1	
	16:00	2,120	1						1		1	
	17:00	2,192	1						1		1	
	18:00	2,295	1						1		1	
	19:00	2,366	1						1		1	
	20:00	2,441	1						1		1	
	21:00	2,446	1	1					1		1	
	22:00	2,318	1						1		1	
	23:00	2,320	1						1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 26 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ω Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Παρασκευή, 26 Ιουνίου 2026	00:00	1,972	1							1	1	
	01:00	1,791	1							1	1	
	02:00	1,685	1							1	1	
	03:00	1,576	1							1	1	
	04:00	1,522	1							1		
	05:00	1,530	1							1		
	06:00	1,612	1							1	1	
	07:00	1,722	1							1	1	
	08:00	1,792	1							1	1	
	09:00	1,845	1							1	1	
	10:00	1,985	1							1	1	
	11:00	2,095	1							1	1	
	12:00	2,205	1							1	1	
	13:00	2,301	1							1	1	
	14:00	2,304	1							1	1	
	15:00	2,264	1							1	1	
	16:00	2,245	1							1	1	
	17:00	2,282	1							1	1	
	18:00	2,456	1	1						1	1	
	19:00	2,529	1	1						1	1	
	20:00	2,561	1	1						1	1	
	21:00	2,627	1	1						1	1	
	22:00	2,541	1	1					1	1	1	
	23:00	2,338	1						1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 27 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Σάββατο, 27 Ιουνίου 2026	00:00	2,164	1						1	1		
	01:00	1,966	1						1	1		
	02:00	1,788	1						1	1		
	03:00	1,676	1						1	1		
	04:00	1,660	1						1	1		
	05:00	1,622	1						1	1		
	06:00	1,658	1						1	1		
	07:00	1,741	1						1	1		
	08:00	1,872	1						1	1		
	09:00	1,977	1						1	1		
	10:00	2,116	1						1	1		
	11:00	2,172	1						1	1		
	12:00	2,227	1						1	1		
	13:00	2,293	1						1	1		
	14:00	2,375	1						1	1		
	15:00	2,384	1						1	1		
	16:00	2,458	1						1	1	1	
	17:00	2,431	1						1	1	1	
	18:00	2,531	1						1	1	1	
	19:00	2,583	1						1	1	1	
	20:00	2,552	1						1	1	1	
	21:00	2,574	1						1	1	1	
	22:00	2,463	1						1	1	1	
	23:00	2,282	1						1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 28 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Κυριακή, 28 Ιουνίου 2026	00:00	2,120	1						1	1		
	01:00	1,943	1						1	1		
	02:00	1,769	1						1	1		
	03:00	1,691	1						1	1		
	04:00	1,652	1						1	1		
	05:00	1,609	1						1	1		
	06:00	1,687	1						1	1		
	07:00	1,771	1						1	1		
	08:00	1,810	1						1	1		
	09:00	1,935	1						1	1		
	10:00	1,976	1						1	1		
	11:00	2,050	1						1	1		
	12:00	2,145	1						1	1		
	13:00	2,213	1						1	1		
	14:00	2,183	1						1	1		
	15:00	2,210	1						1	1		
	16:00	2,192	1						1	1		
	17:00	2,239	1						1	1		
	18:00	2,340	1						1	1		
	19:00	2,378	1						1	1		
	20:00	2,384	1						1	1		
	21:00	2,424	1						1	1		1
	22:00	2,256	1						1	1		
	23:00	2,106	1						1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 29 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Ν Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Δευτέρα, 29 Ιουνίου 2026	00:00	1,900	1						1	1		
	01:00	1,782	1						1	1		
	02:00	1,622	1						1	1		
	03:00	1,562	1						1	1		
	04:00	1,530	1						1	1		
	05:00	1,543	1						1	1		
	06:00	1,612	1						1	1		
	07:00	1,683	1						1	1		
	08:00	1,801	1						1	1		
	09:00	1,882	1						1	1		
	10:00	1,942	1						1	1		
	11:00	1,988	1						1	1		
	12:00	2,044	1						1	1		
	13:00	2,145	1						1	1		
	14:00	2,247	1						1	1		
	15:00	2,242	1						1	1		
	16:00	2,205	1						1	1		
	17:00	2,224	1						1	1		
	18:00	2,337	1						1	1		
	19:00	2,358	1						1	1		
	20:00	2,411	1						1	1		
	21:00	2,392	1						1	1		
	22:00	2,303	1						1	1		
	23:00	2,095	1						1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 30 Ιουνίου 2026									
Αποδιδόμενη Ισχύς (MW)			0,900	0,900	0,300	0,300	0,300	0,300	0,900	0,900	0,900	1,000
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τρίτη, 30 Ιουνίου 2026	00:00	1,960	1						1	1	1	
	01:00	1,772	1							1	1	
	02:00	1,654	1							1	1	
	03:00	1,585	1							1	1	
	04:00	1,539	1							1	1	
	05:00	1,523	1							1	1	
	06:00	1,572	1							1	1	
	07:00	1,703	1							1	1	
	08:00	1,804	1							1	1	
	09:00	1,947	1							1	1	
	10:00	1,986	1							1	1	
	11:00	2,146	1							1	1	
	12:00	2,181	1							1	1	
	13:00	2,291	1							1	1	
	14:00	2,307	1							1	1	
	15:00	2,266	1							1	1	
	16:00	2,270	1							1	1	
	17:00	2,269	1							1	1	
	18:00	2,390	1							1	1	
	19:00	2,422	1							1	1	
	20:00	2,428	1							1	1	
	21:00	2,554	1							1	1	
	22:00	2,385	1							1	1	
	23:00	2,217	1							1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση