

ΗΣ ΟΘΩΝΩΝ			Προτεινόμενος ΗΕΠ		Πέμπτη, 9 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Πέμπτη, 9 Ιουλίου 2026	00:00	116		1		1		
	01:00	103				1		
	02:00	97				1		
	03:00	96				1		
	04:00	96				1		
	05:00	92				1		
	06:00	86				1		
	07:00	86				1		
	08:00	101				1		
	09:00	120		1		1		
	10:00	125		1		1		
	11:00	127		1		1		
	12:00	135		1		1		
	13:00	142		1		1		
	14:00	137		1		1		
	15:00	127		1		1		
	16:00	122		1		1		
	17:00	124		1		1		
	18:00	126		1		1		
	19:00	130		1		1		
	20:00	138		1		1		
	21:00	147		1		1		
	22:00	147		1		1		
	23:00	129		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ			Προτεινόμενος ΗΕΠ		Παρασκευή, 10 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Παρασκευή, 10 Ιουλίου 2026	00:00	114		1		1		
	01:00	105				1		
	02:00	101				1		
	03:00	100				1		
	04:00	99				1		
	05:00	95				1		
	06:00	88				1		
	07:00	88				1		
	08:00	103				1		
	09:00	117		1		1		
	10:00	120		1		1		
	11:00	124		1		1		
	12:00	130		1		1		
	13:00	135		1		1		
	14:00	131		1		1		
	15:00	124		1		1		
	16:00	118		1		1		
	17:00	123		1		1		
	18:00	130		1		1		
	19:00	137		1		1		
	20:00	147		1		1		
	21:00	154		1		1		
	22:00	150		1		1		
	23:00	131		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ			Προτεινόμενος ΗΕΠ		Σάββατο, 11 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Σάββατο, 11 Ιουλίου 2026	00:00	121		1		1		
	01:00	108		1		1		
	02:00	101				1		
	03:00	99				1		
	04:00	97				1		
	05:00	93				1		
	06:00	88				1		
	07:00	88				1		
	08:00	102				1		
	09:00	119		1		1		
	10:00	126		1		1		
	11:00	129		1		1		
	12:00	136		1		1		
	13:00	144		1		1		
	14:00	148		1		1		
	15:00	145		1		1		
	16:00	139		1		1		
	17:00	138		1		1		
	18:00	139		1		1		
	19:00	141		1		1		
	20:00	151		1		1		
	21:00	158		1		1		
	22:00	152		1		1		
	23:00	134		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ			Προτεινόμενος ΗΕΠ		Κυριακή, 12 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Κυριακή, 12 Ιουλίου 2026	00:00	119		1		1		
	01:00	112		1		1		
	02:00	107				1		
	03:00	104				1		
	04:00	100				1		
	05:00	94				1		
	06:00	88				1		
	07:00	91				1		
	08:00	108		1		1		
	09:00	127		1		1		
	10:00	129		1		1		
	11:00	131		1		1		
	12:00	139		1		1		
	13:00	148		1		1		
	14:00	154		1		1		
	15:00	151		1		1		
	16:00	140		1		1		
	17:00	134		1		1		
	18:00	129		1		1		
	19:00	129		1		1		
	20:00	135		1		1		
	21:00	142		1		1		
	22:00	138		1		1		
	23:00	125		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ			Προτεινόμενος ΗΕΠ		Δευτέρα, 13 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Δευτέρα, 13 Ιουλίου 2026	00:00	113		1		1		
	01:00	104				1		
	02:00	99				1		
	03:00	98				1		
	04:00	96				1		
	05:00	92				1		
	06:00	87				1		
	07:00	89				1		
	08:00	105				1		
	09:00	122		1		1		
	10:00	131		1		1		
	11:00	135		1		1		
	12:00	139		1		1		
	13:00	142		1		1		
	14:00	143		1		1		
	15:00	137		1		1		
	16:00	130		1		1		
	17:00	127		1		1		
	18:00	126		1		1		
	19:00	128		1		1		
	20:00	132		1		1		
	21:00	137		1		1		
	22:00	133		1		1		
	23:00	122		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ			Προτεινόμενος ΗΕΠ		Τρίτη, 14 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Τρίτη, 14 Ιουλίου 2026	00:00	116		1		1		
	01:00	111		1		1		
	02:00	107				1		
	03:00	102				1		
	04:00	99				1		
	05:00	93				1		
	06:00	86				1		
	07:00	85				1		
	08:00	101				1		
	09:00	119		1		1		
	10:00	130		1		1		
	11:00	134		1		1		
	12:00	136		1		1		
	13:00	137		1		1		
	14:00	137		1		1		
	15:00	128		1		1		
	16:00	121		1		1		
	17:00	119		1		1		
	18:00	120		1		1		
	19:00	123		1		1		
	20:00	129		1		1		
	21:00	132		1		1		
	22:00	129		1		1		
	23:00	120		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ			Προτεινόμενος ΗΕΠ		Τετάρτη, 15 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Τετάρτη, 15 Ιουλίου 2026	00:00	109		1		1		
	01:00	99				1		
	02:00	96				1		
	03:00	94				1		
	04:00	92				1		
	05:00	88				1		
	06:00	82				1		
	07:00	83				1		
	08:00	99				1		
	09:00	115		1		1		
	10:00	124		1		1		
	11:00	128		1		1		
	12:00	132		1		1		
	13:00	135		1		1		
	14:00	133		1		1		
	15:00	123		1		1		
	16:00	116		1		1		
	17:00	112		1		1		
	18:00	114		1		1		
	19:00	120		1		1		
	20:00	129		1		1		
	21:00	135		1		1		
	22:00	132		1		1		
	23:00	121		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης