

ΗΣ ΟΘΩΝΩΝ		Προτεινόμενος ΗΕΠ			Πέμπτη, 30 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Πέμπτη, 30 Ιουλίου 2026	00:00	148				1	1	
	01:00	137				1	1	
	02:00	127				1	1	
	03:00	121				1	1	
	04:00	117				1	1	
	05:00	112				1	1	
	06:00	107				1	1	
	07:00	107				1	1	
	08:00	123				1	1	
	09:00	141				1	1	
	10:00	153				1	1	
	11:00	162				1	1	
	12:00	169				1	1	
	13:00	176				1	1	
	14:00	177				1	1	
	15:00	173				1	1	
	16:00	168				1	1	
	17:00	162				1	1	
	18:00	161				1	1	
	19:00	169				1	1	
	20:00	178				1	1	
	21:00	182				1	1	
	22:00	177				1	1	
	23:00	163				1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Προτεινόμενος ΗΕΠ			Παρασκευή, 31 Ιουλίου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Παρασκευή, 31 Ιουλίου 2026	00:00	154				1	1	
	01:00	140				1	1	
	02:00	129				1	1	
	03:00	123				1	1	
	04:00	117				1	1	
	05:00	112				1	1	
	06:00	107				1	1	
	07:00	107				1	1	
	08:00	120				1	1	
	09:00	136				1	1	
	10:00	149				1	1	
	11:00	159				1	1	
	12:00	168				1	1	
	13:00	175				1	1	
	14:00	179				1	1	
	15:00	178				1	1	
	16:00	174				1	1	
	17:00	170				1	1	
	18:00	168				1	1	
	19:00	174				1	1	
	20:00	182				1	1	
	21:00	190				1	1	
	22:00	188				1	1	
	23:00	176				1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Προτεινόμενος ΗΕΠ			Σάββατο, 1 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Σάββατο, 1 Αυγούστου 2026	00:00	157				1	1	
	01:00	142				1	1	
	02:00	133				1	1	
	03:00	126				1	1	
	04:00	119				1	1	
	05:00	112				1	1	
	06:00	107				1	1	
	07:00	106				1	1	
	08:00	127				1	1	
	09:00	153				1	1	
	10:00	179				1	1	
	11:00	196		1		1	1	
	12:00	207		1		1	1	
	13:00	212		1		1	1	
	14:00	216		1		1	1	
	15:00	216		1		1	1	
	16:00	209		1		1	1	
	17:00	202		1		1	1	
	18:00	194				1	1	
	19:00	193				1	1	
	20:00	196				1	1	
	21:00	192				1	1	
	22:00	179				1	1	
	23:00	161				1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Προτεινόμενος ΗΕΠ			Κυριακή, 2 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Κυριακή, 2 Αυγούστου 2026	00:00	150				1	1	
	01:00	140				1	1	
	02:00	134				1	1	
	03:00	128				1	1	
	04:00	122				1	1	
	05:00	116				1	1	
	06:00	114				1	1	
	07:00	120				1	1	
	08:00	137				1	1	
	09:00	157				1	1	
	10:00	181				1	1	
	11:00	197				1	1	
	12:00	207				1	1	
	13:00	215		1		1	1	
	14:00	220		1		1	1	
	15:00	221		1		1	1	
	16:00	214		1		1	1	
	17:00	205				1	1	
	18:00	192				1	1	
	19:00	188				1	1	
	20:00	186				1	1	
	21:00	180				1	1	
	22:00	170				1	1	
	23:00	158				1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Προτεινόμενος ΗΕΠ			Δευτέρα, 3 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Δευτέρα, 3 Αυγούστου 2026	00:00	155				1	1	
	01:00	145				1	1	
	02:00	140				1	1	
	03:00	135				1	1	
	04:00	129				1	1	
	05:00	122				1	1	
	06:00	119				1	1	
	07:00	124				1	1	
	08:00	140				1	1	
	09:00	159				1	1	
	10:00	182				1	1	
	11:00	199				1	1	
	12:00	211		1		1	1	
	13:00	219		1		1	1	
	14:00	224		1		1	1	
	15:00	227		1		1	1	
	16:00	220		1		1	1	
	17:00	213		1		1	1	
	18:00	203				1	1	
	19:00	191				1	1	
	20:00	189				1	1	
	21:00	185				1	1	
	22:00	178				1	1	
	23:00	167				1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Προτεινόμενος ΗΕΠ			Τρίτη, 4 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Τρίτη, 4 Αυγούστου 2026	00:00	165				1	1	
	01:00	154				1	1	
	02:00	146				1	1	
	03:00	140				1	1	
	04:00	133				1	1	
	05:00	125				1	1	
	06:00	119				1	1	
	07:00	120				1	1	
	08:00	143				1	1	
	09:00	164				1	1	
	10:00	181				1	1	
	11:00	194				1	1	
	12:00	205				1	1	
	13:00	214		1		1	1	
	14:00	222		1		1	1	
	15:00	226		1		1	1	
	16:00	221		1		1	1	
	17:00	215		1		1	1	
	18:00	209				1	1	
	19:00	199				1	1	
	20:00	199				1	1	
	21:00	195				1	1	
	22:00	189				1	1	
	23:00	179				1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Προτεινόμενος ΗΕΠ			Τετάρτη, 5 Αυγούστου 2026			
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6
Τετάρτη, 5 Αυγούστου 2026	00:00	168				1	1	
	01:00	156				1	1	
	02:00	145				1	1	
	03:00	135				1	1	
	04:00	124				1	1	
	05:00	115				1	1	
	06:00	108				1	1	
	07:00	109				1	1	
	08:00	129				1	1	
	09:00	155				1	1	
	10:00	177				1	1	
	11:00	195				1	1	
	12:00	207				1	1	
	13:00	217		1		1	1	
	14:00	222		1		1	1	
	15:00	223		1		1	1	
	16:00	218		1		1	1	
	17:00	210				1	1	
	18:00	204				1	1	
	19:00	194				1	1	
	20:00	194				1	1	
	21:00	189				1	1	
	22:00	184				1	1	
	23:00	175				1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης