

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα, 20 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Δευτέρα, 20 Ιουλίου 2026	00:00	47,65	1	1	1	1	1	1		1	1	1	2	
	01:00	44,90	1	1	1	1	1	1		1	1	1		
	02:00	43,37	1	1	1	1	1	1		1	1	1		
	03:00	41,91	1	1	1	1	1	1		1	1	1		
	04:00	40,57	1	1	1	1	1	1		1	1	1		
	05:00	39,79	1	1	1	1	1	1		1	1	1		
	06:00	40,68	1	1	1	1	1	1		1	1	1		
	07:00	45,27	1	1	1	1	1	1		1	1	1		
	08:00	51,50	1	1	1	1	1	1		1	1	1		7
	09:00	56,40	1	1	1	1	1	1		1	1	1		13
	10:00	59,68	1	1	1	1	1	1		1	1	1		17
	11:00	61,52	1	1	1	1	1	1		1	1	1		19
	12:00	62,73	1	1	1	1	1	1		1	1	1	1	20
	13:00	63,39	1	1	1	1	1	1		1	1	1	2	20
	14:00	63,71	1	1	1	1	1	1		1	1	1	2	20
	15:00	63,06	1	1	1	1	1	1		1	1	1	2	20
	16:00	62,39	1	1	1	1	1	1		1	1	1	2	20
	17:00	62,76	1	1	1	1	1	1		1	1	1	2	20
	18:00	63,45	1	1	1	1	1	1		1	1	1	2	20
	19:00	63,36	1	1	1	1	1	1		1	1	1	2	20
	20:00	59,80	1	1	1	1	1	1		1	1	1	1	17
	21:00	58,30	1	1	1	1	1	1		1	1	1		15
	22:00	57,14	1	1	1	1	1	1		1	1	1		14
	23:00	53,32	1	1	1	1	1	1		1	1	1		9

Πέντε φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης