

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																			Wednesday, July 1, 2026					
Αποδιδόμενη Ισχύς (MW)						18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	14.90	14.90	1.00	17.10	17.10	17.10	17.10	17.10	17.10	17.10			
TE (MW)						14.00	14.00	14.00	5.00	5.00	5.00	5.60	6.60	3.00	3.00	1.00	6.00	6.00	6.00	6.00	6.00	6.00	6.00				
H R O U S E	Χρονική στιγμή	Πρόβλεψη Μέσου ημερησίου φορτίου (MW)	Πρόβλεψη θερμικής παραγωγής (MW)	Πρόβλεψη Αιολικής παραγωγής (MW)	Πρόβλεψη Φωτοβολταϊκής παραγωγής (MW)	ΑΗΣ ΣΟΡΔΗΣ								ΘΗΣ Ν.ΡΟΔΟΥ							Στεφόμενη υπερδύναμη (MW)	Set-point Αιολικών Πάρκων (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)			
						DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	AEP 7	AEP 8	ΦΟΡΤΑ ΗΖ	DIESEL 1	DIESEL 2	DIESEL 3					DIESEL 4	DIESEL 5	DIESEL 6
Wednesday, July 1, 2026	00:00	138.07	116.46	21.62	0.00		1	1						1				1	1					29.84	41.42	80%	25,917
	01:00	130.15	108.32	21.83	0.00		1	1						1				1	1					37.98	39.04	74%	24,547
	02:00	124.46	104.83	19.63	0.00		1	1						1				1	1					41.47	37.34	72%	23,944
	03:00	120.35	101.52	18.83	0.00		1	1						1				1	1					44.78	36.10	69%	23,362
	04:00	117.99	99.03	18.96	0.00		1	1						1				1	1					47.27	35.40	68%	22,917
	05:00	118.60	100.32	18.28	0.00		1	1						1				1	1					45.98	35.58	69%	23,148
	06:00	125.18	104.92	18.97	1.30		1	1						1				1	1					41.38	37.16	72%	23,959
	07:00	140.08	115.13	19.43	5.52	1	1	1						1				1	1					49.17	40.37	70%	25,356
	08:00	156.57	128.21	18.09	10.28	1	1	1						1				1	1					53.19	43.89	71%	27,019
	09:00	168.83	134.63	19.50	14.70	1	1	1						1				1	1					46.77	46.24	74%	27,993
	10:00	175.29	136.74	20.11	18.44	1	1	1						1				1	1					44.66	47.06	75%	28,333
	11:00	178.92	137.82	19.88	21.23	1	1	1						1				1	1					43.58	47.31	76%	28,504
	12:00	183.05	139.72	20.47	22.87	1	1	1						1				1	1					41.68	48.06	77%	28,807
	13:00	187.63	144.68	19.71	23.24	1	1	1						1				1	1					36.72	48.85	80%	29,585
	14:00	188.73	146.66	19.67	22.41	1	1	1						1				1	1					34.74	48.85	81%	29,892
	15:00	186.10	143.06	22.71	20.33	1	1	1						1				1	1					38.34	48.85	79%	29,332
	16:00	184.83	138.06	29.59	17.18	1	1	1						1				1	1					43.34	48.85	76%	28,544
	17:00	184.29	139.12	32.04	13.13	1	1	1						1				1	1					42.28	48.85	77%	28,711
	18:00	184.92	145.14	31.27	8.51	1	1	1						1				1	1					36.26	48.85	80%	29,656
	19:00	183.30	148.50	31.03	3.78	1	1	1						1				1	1					32.90	48.85	82%	30,175
	20:00	177.39	144.94	32.02	0.43	1	1	1						1				1	1					36.46	48.85	80%	29,625
	21:00	170.14	137.27	32.87	0.00	1	1	1						1				1	1					44.13	48.85	76%	28,418
	22:00	159.61	127.22	32.39	0.00	1	1	1						1				1	1					54.18	47.88	70%	26,785
	23:00	147.87	115.77	32.10	0.00	1	1	1						1				1	1					48.53	44.36	70%	25,395
		3832.35 MWh																				ΑΩΔ: 21.84		649,923 €			

Παρατηρήσεις:

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης