

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 15 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η ε π ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Τετάρτη, 15 Ιουλίου 2026	00:00	1,934			1	1	1		1	
	01:00	1,776				1	1		1	
	02:00	1,666				1	1		1	
	03:00	1,588				1	1		1	
	04:00	1,500				1	1		1	
	05:00	1,482				1	1		1	
	06:00	1,495				1	1		1	
	07:00	1,614				1	1		1	
	08:00	1,753				1	1		1	
	09:00	1,933				1	1		1	
	10:00	2,059				1	1		1	
	11:00	2,127				1	1		1	
	12:00	2,151				1	1		1	
	13:00	2,093				1	1		1	
	14:00	2,138				1	1		1	
	15:00	2,136				1	1		1	1
	16:00	2,155				1	1		1	1
	17:00	2,259				1	1		1	1
	18:00	2,328				1	1		1	1
	19:00	2,404				1	1		1	1
	20:00	2,421				1	1		1	1
	21:00	2,426				1	1		1	1
	22:00	2,346				1	1		1	1
	23:00	2,200				1	1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 16 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Πέμπτη, 16 Ιουλίου 2026	00:00	2,051				1	1		1	1
	01:00	1,889				1	1		1	
	02:00	1,765				1	1		1	
	03:00	1,677				1	1		1	
	04:00	1,598				1	1		1	
	05:00	1,580				1	1		1	
	06:00	1,587				1	1		1	
	07:00	1,747				1	1		1	
	08:00	1,862				1	1		1	
	09:00	1,969				1	1			1
	10:00	2,132				1	1			1
	11:00	2,207				1	1			1
	12:00	2,172				1	1			1
	13:00	2,211				1	1			1
	14:00	2,211				1	1			1
	15:00	2,214				1	1		1	1
	16:00	2,218				1	1		1	1
	17:00	2,322				1	1		1	1
	18:00	2,453				1	1		1	1
	19:00	2,614				1	1		1	1
	20:00	2,567				1	1		1	1
	21:00	2,472				1	1		1	1
	22:00	2,418				1	1		1	1
	23:00	2,320				1	1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 17 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η ε π ε ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Παρασκευή, 17 Ιουλίου 2026	00:00	2,092				1	1		1	1
	01:00	1,962				1	1		1	
	02:00	1,869				1	1		1	
	03:00	1,761				1	1		1	
	04:00	1,667				1	1		1	
	05:00	1,640				1	1		1	
	06:00	1,628				1	1		1	
	07:00	1,780				1	1		1	
	08:00	1,906				1	1		1	
	09:00	2,034				1	1			1
	10:00	2,180				1	1			1
	11:00	2,205				1	1			1
	12:00	2,264				1	1			1
	13:00	2,269				1	1			1
	14:00	2,330				1	1			1
	15:00	2,308				1	1		1	1
	16:00	2,307				1	1		1	1
	17:00	2,470				1	1		1	1
	18:00	2,533				1	1		1	1
	19:00	2,691				1	1		1	1
	20:00	2,691				1	1		1	1
	21:00	2,698				1	1		1	1
	22:00	2,557				1	1		1	1
	23:00	2,458				1	1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 18 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Σάββατο, 18 Ιουλίου 2026	00:00	2,247				1	1		1	1
	01:00	2,103				1	1		1	
	02:00	2,032				1	1		1	
	03:00	1,914				1	1		1	
	04:00	1,798				1	1		1	
	05:00	1,754				1	1		1	
	06:00	1,764				1	1		1	
	07:00	1,871				1	1		1	
	08:00	1,997				1	1		1	
	09:00	2,183				1	1		1	1
	10:00	2,323					1		1	1
	11:00	2,323					1		1	1
	12:00	2,348					1		1	1
	13:00	2,405				1	1		1	1
	14:00	2,408				1	1		1	1
	15:00	2,423				1	1		1	1
	16:00	2,440				1	1		1	1
	17:00	2,567				1	1		1	1
	18:00	2,708				1	1		1	1
	19:00	2,817				1	1		1	1
	20:00	2,813				1	1		1	1
	21:00	2,860				1	1		1	1
	22:00	2,673				1	1		1	1
	23:00	2,543				1	1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 19 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Κυριακή, 19 Ιουλίου 2026	00:00	2,367				1	1		1	1
	01:00	2,256				1	1		1	1
	02:00	2,179				1	1		1	
	03:00	2,060				1	1		1	
	04:00	1,958				1	1		1	
	05:00	1,949				1	1		1	
	06:00	1,912				1	1		1	
	07:00	2,018				1	1		1	
	08:00	2,121				1	1		1	
	09:00	2,244				1	1		1	1
	10:00	2,354				1	1		1	1
	11:00	2,468				1	1		1	1
	12:00	2,469				1	1		1	1
	13:00	2,525				1	1		1	1
	14:00	2,554				1	1		1	1
	15:00	2,584				1	1		1	1
	16:00	2,625				1	1		1	1
	17:00	2,668			1	1	1		1	1
	18:00	2,772			1	1	1		1	1
	19:00	2,922			1	1	1		1	1
	20:00	2,827			1	1	1		1	1
	21:00	2,914			1	1	1		1	1
	22:00	2,814			1	1			1	1
	23:00	2,681			1	1			1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 20 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Δευτέρα, 20 Ιουλίου 2026	00:00	2,499			1	1			1	1
	01:00	2,363			1	1			1	1
	02:00	2,222			1	1			1	
	03:00	2,038			1	1			1	
	04:00	1,926			1	1			1	
	05:00	1,878			1	1			1	
	06:00	1,860			1	1			1	
	07:00	2,027			1	1			1	
	08:00	2,193			1	1			1	
	09:00	2,420			1	1			1	1
	10:00	2,534			1	1			1	1
	11:00	2,535			1	1			1	1
	12:00	2,551			1	1			1	1
	13:00	2,612			1	1			1	1
	14:00	2,717			1	1			1	1
	15:00	2,725			1	1			1	1
	16:00	2,777			1	1			1	1
	17:00	2,865			1	1			1	1
	18:00	2,983			1	1		1	1	1
	19:00	3,089			1	1		1	1	1
	20:00	3,048			1	1		1	1	1
	21:00	3,105			1	1		1	1	1
	22:00	2,996			1	1		1	1	1
	23:00	2,878			1	1		1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 21 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (x1)
Τρίτη, 21 Ιουλίου 2026	00:00	2,694			1	1		1		1
	01:00	2,528			1	1		1		1
	02:00	2,418			1	1		1		
	03:00	2,273			1	1		1		
	04:00	2,118			1	1		1		
	05:00	2,060			1	1		1		
	06:00	2,069			1	1		1		
	07:00	2,145			1	1		1		
	08:00	2,291			1	1		1		
	09:00	2,580			1	1		1		1
	10:00	2,657			1	1		1		1
	11:00	2,714			1	1		1		1
	12:00	2,723			1	1		1		1
	13:00	2,741			1	1		1		1
	14:00	2,845			1	1		1		1
	15:00	2,850			1	1		1		1
	16:00	2,853			1	1		1		1
	17:00	2,760			1	1		1		1
	18:00	2,978			1	1		1	1	1
	19:00	3,073			1	1		1	1	1
	20:00	3,083			1	1		1	1	1
	21:00	3,131			1	1		1	1	1
	22:00	3,039			1	1		1	1	1
	23:00	2,891			1	1		1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση