

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 30 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Πέμπτη, 30 Ιουλίου 2026	00:00	2,313		1	1					1
	01:00	2,136		1	1					1
	02:00	1,993		1	1					1
	03:00	1,886		1	1					1
	04:00	1,825		1	1					1
	05:00	1,813		1	1					1
	06:00	1,848		1	1					1
	07:00	1,922		1	1					1
	08:00	2,028		1	1					1
	09:00	2,169		1	1					1
	10:00	2,298		1	1					1
	11:00	2,375		1	1	1				1
	12:00	2,403		1	1	1				1
	13:00	2,403		1	1	1				1
	14:00	2,400		1	1	1				1
	15:00	2,405		1	1	1				1
	16:00	2,444		1	1	1				1
	17:00	2,540		1	1	1				1
	18:00	2,668		1	1	1				1
	19:00	2,789		1	1	1				1
	20:00	2,838		1	1	1				1
	21:00	2,815		1	1	1				1
	22:00	2,708		1	1	1				1
	23:00	2,549		1	1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 31 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Παρασκευή, 31 Ιουλίου 2026	00:00	2,395		1	1					1
	01:00	2,212		1	1					1
	02:00	2,050		1	1					1
	03:00	1,924		1	1					1
	04:00	1,845		1	1					1
	05:00	1,820		1	1					1
	06:00	1,850		1	1					1
	07:00	1,920		1	1					1
	08:00	2,028		1	1					1
	09:00	2,171		1	1					1
	10:00	2,302		1	1					1
	11:00	2,375		1	1	1				1
	12:00	2,404		1	1	1				1
	13:00	2,400		1	1	1				1
	14:00	2,396		1	1	1				1
	15:00	2,405		1	1	1				1
	16:00	2,455		1	1	1				1
	17:00	2,553		1	1	1				1
	18:00	2,681		1	1	1				1
	19:00	2,800		1	1	1				1
	20:00	2,860		1	1	1				1
	21:00	2,838		1	1	1				1
	22:00	2,741		1	1	1				1
	23:00	2,595		1	1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 1 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Σάββατο, 1 Αυγούστου 2026	00:00	2,431		1	1	1				1
	01:00	2,269		1	1					1
	02:00	2,125		1	1					1
	03:00	2,013		1	1					1
	04:00	1,942		1	1					1
	05:00	1,913		1	1					1
	06:00	1,932		1	1					1
	07:00	1,993		1	1					1
	08:00	2,071		1	1					1
	09:00	2,182		1	1					1
	10:00	2,289		1	1					1
	11:00	2,355		1	1	1				1
	12:00	2,386		1	1	1				1
	13:00	2,376		1	1	1				1
	14:00	2,359		1	1	1				1
	15:00	2,352		1	1	1				1
	16:00	2,388		1	1	1				1
	17:00	2,477		1	1	1				1
	18:00	2,599		1	1	1				1
	19:00	2,722		1	1	1				1
	20:00	2,800		1	1	1				1
	21:00	2,798		1	1	1				1
	22:00	2,718		1	1	1				1
	23:00	2,594		1	1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ				Κυριακή, 2 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Κυριακή, 2 Αυγούστου 2026	00:00	2,324		1	1	1				
	01:00	2,182		1	1	1				
	02:00	2,058		1	1	1				
	03:00	1,960		1	1	1				
	04:00	1,898		1	1	1				
	05:00	1,873		1	1	1				
	06:00	1,889		1	1	1				
	07:00	1,945		1	1	1				
	08:00	2,016		1	1	1				
	09:00	2,121		1	1	1				
	10:00	2,218		1	1	1				
	11:00	2,282		1	1	1				1
	12:00	2,314		1	1	1				1
	13:00	2,298		1	1	1				1
	14:00	2,279		1	1	1				1
	15:00	2,264		1	1	1				1
	16:00	2,278		1	1	1				1
	17:00	2,359		1	1	1				1
	18:00	2,485		1	1	1				1
	19:00	2,616		1	1	1				1
	20:00	2,689		1	1	1				1
	21:00	2,684		1	1	1				1
	22:00	2,602		1	1	1				1
	23:00	2,476		1	1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 3 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Δευτέρα, 3 Αυγούστου 2026	00:00	2,215		1	1	1				
	01:00	2,060		1	1	1				
	02:00	1,923		1	1	1				
	03:00	1,816		1	1	1				
	04:00	1,750		1	1	1				
	05:00	1,732		1	1	1				
	06:00	1,757		1	1	1				
	07:00	1,835		1	1	1				
	08:00	1,931		1	1	1				
	09:00	2,056		1	1	1				
	10:00	2,176		1	1	1				
	11:00	2,250		1	1	1				
	12:00	2,287		1	1	1				1
	13:00	2,266		1	1	1				1
	14:00	2,248		1	1	1				1
	15:00	2,242		1	1	1				1
	16:00	2,252		1	1	1				1
	17:00	2,337		1	1	1				1
	18:00	2,448		1	1	1				1
	19:00	2,590		1	1	1				1
	20:00	2,660		1	1	1				1
	21:00	2,654		1	1	1				1
	22:00	2,562		1	1	1				1
	23:00	2,425		1	1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ				Τρίτη, 4 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000	
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)	
Τρίτη, 4 Αυγούστου 2026	00:00	2,198		1	1	1					
	01:00	2,016		1	1	1					
	02:00	1,860		1	1	1					
	03:00	1,745		1	1	1					
	04:00	1,679		1	1	1					
	05:00	1,666		1	1	1					
	06:00	1,704		1	1	1					
	07:00	1,792		1	1	1					
	08:00	1,900		1	1	1					
	09:00	2,043		1	1	1					
	10:00	2,179		1	1	1					
	11:00	2,267		1	1	1				1	
	12:00	2,302		1	1	1				1	
	13:00	2,283		1	1	1				1	
	14:00	2,263		1	1	1				1	
	15:00	2,257		1	1	1				1	
	16:00	2,274		1	1	1				1	
	17:00	2,358		1	1	1				1	
	18:00	2,480		1	1	1				1	
	19:00	2,625		1	1	1				1	
	20:00	2,698		1	1	1				1	
	21:00	2,688		1	1	1				1	
	22:00	2,586		1	1	1				1	
	23:00	2,427		1	1	1				1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 5 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			0,300	0,950	0,950	0,950	0,850	0,850	0,850	1,000
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Τετάρτη, 5 Αυγούστου 2026	00:00	2,226		1	1	1				
	01:00	2,043		1	1	1				
	02:00	1,892		1	1	1				
	03:00	1,784		1	1	1				
	04:00	1,724		1	1	1				
	05:00	1,715		1	1	1				
	06:00	1,754		1	1	1				
	07:00	1,837		1	1	1				
	08:00	1,934		1	1	1				
	09:00	2,057		1	1	1				
	10:00	2,179		1	1	1				
	11:00	2,259		1	1	1				
	12:00	2,285		1	1	1				1
	13:00	2,266		1	1	1				1
	14:00	2,246		1	1	1				1
	15:00	2,245		1	1	1				1
	16:00	2,275		1	1	1				1
	17:00	2,368		1	1	1				1
	18:00	2,501		1	1	1				1
	19:00	2,645		1	1	1				1
	20:00	2,721		1	1	1				1
	21:00	2,707		1	1	1				1
	22:00	2,602		1	1	1				1
	23:00	2,439		1	1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση