

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 25 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Πέμπτη, 25 Ιουνίου 2026	00:00	1,873		1		1	1			
	01:00	1,738		1		1	1			
	02:00	1,628				1	1			
	03:00	1,620				1	1			
	04:00	1,556				1	1			
	05:00	1,612				1	1			
	06:00	1,633				1	1			
	07:00	1,877				1	1		1	
	08:00	2,016				1	1		1	
	09:00	2,077				1	1		1	
	10:00	2,051	1			1	1			
	11:00	2,146	1			1	1			
	12:00	2,144	1			1	1			
	13:00	2,232	1			1	1			
	14:00	2,183	1			1	1			
	15:00	2,072	1			1	1			
	16:00	1,940	1			1	1			
	17:00	2,092	1			1	1			
	18:00	2,330	1			1	1			
	19:00	2,541	1			1	1			
	20:00	2,568	1			1	1	1		
	21:00	2,636				1	1	1		
	22:00	2,394				1	1	1		
	23:00	2,191				1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 26 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Παρασκευή, 26 Ιουνίου 2026	00:00	2,011				1	1	1		
	01:00	1,842				1	1	1		
	02:00	1,719				1	1			
	03:00	1,643				1	1			
	04:00	1,610				1	1			
	05:00	1,622				1	1			
	06:00	1,463				1	1			
	07:00	1,740				1	1		1	
	08:00	2,134				1	1		1	
	09:00	2,250				1	1	1	1	
	10:00	2,146				1		1	1	
	11:00	2,214				1		1	1	
	12:00	2,341				1		1	1	
	13:00	2,347				1		1	1	
	14:00	2,294		1		1		1	1	
	15:00	2,136		1		1			1	
	16:00	2,137		1		1			1	
	17:00	2,215		1		1			1	
	18:00	2,455		1		1			1	
	19:00	2,718		1		1	1		1	
	20:00	2,694		1		1	1		1	
	21:00	2,699		1		1	1		1	
	22:00	2,459		1		1	1			
	23:00	2,326		1		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 27 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Σάββατο, 27 Ιουνίου 2026	00:00	2,182		1		1	1			
	01:00	1,972		1		1	1			
	02:00	1,852		1		1	1			
	03:00	1,800		1		1	1			
	04:00	1,703		1			1			
	05:00	1,691		1			1			
	06:00	1,693		1			1			
	07:00	1,873	1	1			1			
	08:00	2,028	1	1			1			
	09:00	2,108	1	1			1			
	10:00	2,127	1	1			1			
	11:00	2,150	1	1			1			
	12:00	2,217	1	1			1			
	13:00	2,322	1	1			1			
	14:00	2,263	1				1		1	
	15:00	2,231	1				1		1	
	16:00	2,191	1				1		1	
	17:00	2,353	1				1		1	
	18:00	2,608	1			1	1		1	
	19:00	2,675	1			1	1		1	
	20:00	2,626	1			1	1		1	
	21:00	2,676	1			1	1		1	
	22:00	2,436	1			1	1		1	
	23:00	2,254				1	1		1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 28 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Κυριακή, 28 Ιουνίου 2026	00:00	2,089				1	1		1	
	01:00	1,887				1	1		1	
	02:00	1,742				1	1		1	
	03:00	1,674				1	1			
	04:00	1,667				1	1			
	05:00	1,683				1	1			
	06:00	1,646				1	1			
	07:00	1,848		1		1	1			
	08:00	1,996		1		1	1			
	09:00	2,091		1		1	1			
	10:00	2,095		1		1	1			
	11:00	2,128		1		1	1			
	12:00	2,244		1		1	1			
	13:00	2,232		1		1	1			
	14:00	2,108		1		1	1			
	15:00	2,051		1		1	1			
	16:00	2,031		1		1	1			
	17:00	2,170		1		1	1			
	18:00	2,388		1		1	1			
	19:00	2,575	1	1		1	1			
	20:00	2,560	1	1		1	1			
	21:00	2,633	1	1		1	1			
	22:00	2,370		1		1	1			
	23:00	2,191		1		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 29 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Δευτέρα, 29 Ιουνίου 2026	00:00	1,979		1		1	1			
	01:00	1,782		1		1	1			
	02:00	1,709		1		1				
	03:00	1,679		1		1				
	04:00	1,612		1		1				
	05:00	1,661		1		1				
	06:00	1,711		1		1				
	07:00	1,826	1	1		1				
	08:00	2,000	1	1		1				
	09:00	2,143	1	1		1				
	10:00	2,295	1	1		1				
	11:00	2,148	1	1		1				
	12:00	2,280	1	1		1				
	13:00	2,395	1	1		1				
	14:00	2,335	1	1		1				
	15:00	2,142	1	1		1				
	16:00	2,125	1	1		1				
	17:00	2,255	1	1		1				
	18:00	2,462	1	1		1				
	19:00	2,643	1	1		1	1			
	20:00	2,694	1	1		1	1			
	21:00	2,825	1	1		1	1			
	22:00	2,597	1	1		1	1			
	23:00	2,436		1		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 30 Ιουνίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τρίτη, 30 Ιουνίου 2026	00:00	2,202		1		1	1			
	01:00	2,053		1		1	1			
	02:00	1,919		1		1	1			
	03:00	1,818		1		1	1			
	04:00	1,790		1			1			
	05:00	1,792		1			1			
	06:00	1,788		1			1			
	07:00	2,029		1			1		1	
	08:00	2,210		1			1		1	
	09:00	2,263		1			1		1	
	10:00	2,242		1			1		1	
	11:00	2,275		1			1		1	
	12:00	2,435		1			1		1	
	13:00	2,567		1			1		1	
	14:00	2,515		1			1		1	
	15:00	2,390		1			1		1	
	16:00	2,373		1			1		1	
	17:00	2,414		1			1		1	
	18:00	2,641		1			1	1	1	
	19:00	2,778		1			1	1	1	
	20:00	2,812		1			1	1	1	
	21:00	2,957		1			1	1	1	
	22:00	2,732		1			1	1	1	
	23:00	2,574		1			1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 1 Ιουλίου 2026							
Αποδιδόμενη Ισχύς (MW)			0,900	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τετάρτη, 1 Ιουλίου 2026	00:00	2,301		1			1	1		
	01:00	2,087		1			1	1		
	02:00	1,950		1			1	1		
	03:00	1,891		1			1	1		
	04:00	1,812					1	1		
	05:00	1,707					1	1		
	06:00	1,695					1	1		
	07:00	1,967	1				1	1		
	08:00	2,165	1				1	1		
	09:00	2,341	1				1	1		
	10:00	2,295	1				1	1		
	11:00	2,280	1				1	1		
	12:00	2,383	1				1	1		
	13:00	2,465	1				1	1		
	14:00	2,513	1				1	1		
	15:00	2,335	1				1	1		
	16:00	2,275	1				1	1	1	
	17:00	2,354					1	1	1	
	18:00	2,549					1	1	1	
	19:00	2,704				1	1	1	1	
	20:00	2,882				1	1	1	1	
	21:00	3,034				1	1	1	1	
	22:00	2,822				1	1	1	1	
	23:00	2,538				1	1	1		

Το διάστημα 5:00-12:00 πραγματοποιήθηκαν προγραμματισμένες εργασίες στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης