

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Παρασκευή, 3 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Παρασκευή, 3 Ιουλίου 2026	00:00	2,317				1	1	1		
	01:00	2,129				1	1	1		
	02:00	1,971				1	1	1		
	03:00	1,837				1	1	1		
	04:00	1,767				1	1	1		
	05:00	1,749				1	1	1		
	06:00	1,791				1	1	1		
	07:00	1,969				1	1	1		
	08:00	2,213				1	1	1		
	09:00	2,335				1	1	1		
	10:00	2,380				1	1	1		
	11:00	2,430				1	1	1		
	12:00	2,512				1	1	1		
	13:00	2,581				1	1	1		
	14:00	2,617				1	1	1	1	
	15:00	2,528				1	1	1	1	
	16:00	2,468				1	1	1	1	
	17:00	2,491				1	1	1	1	
	18:00	2,648				1	1	1	1	
	19:00	2,924				1	1	1	1	
	20:00	3,093				1	1	1	1	
	21:00	3,114				1	1	1	1	
	22:00	2,933				1	1	1	1	
	23:00	2,713				1	1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Σάββατο, 4 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Σ Τ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Σάββατο, 4 Ιουλίου 2026	00:00	2,613				1	1	1	1	
	01:00	2,396				1	1	1		
	02:00	2,207				1	1	1		
	03:00	2,086				1	1	1		
	04:00	2,017				1	1	1		
	05:00	1,961				1	1	1		
	06:00	1,945				1	1	1		
	07:00	2,044				1	1	1		
	08:00	2,232				1	1	1		
	09:00	2,357				1	1	1		
	10:00	2,398				1	1	1		
	11:00	2,426				1	1	1		
	12:00	2,479				1	1	1		
	13:00	2,554				1	1	1		
	14:00	2,586				1	1	1		
	15:00	2,545				1	1	1		
	16:00	2,523				1	1	1		
	17:00	2,606				1	1	1	1	
	18:00	2,828				1	1	1	1	
	19:00	3,106				1	1	1	1	
	20:00	3,204				1	1	1	1	
	21:00	3,170				1	1	1	1	
	22:00	2,836				1	1	1	1	
	23:00	2,585				1	1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Κυριακή, 5 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η ε ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Κυριακή, 5 Ιουλίου 2026	00:00	2,486				1	1	1		
	01:00	2,340				1	1	1		
	02:00	2,209				1	1	1		
	03:00	2,114				1	1	1		
	04:00	2,052				1	1	1		
	05:00	2,015				1	1	1		
	06:00	2,023				1	1	1		
	07:00	2,047				1	1	1		
	08:00	2,187				1	1	1		
	09:00	2,317				1	1	1		
	10:00	2,343				1	1	1		
	11:00	2,327				1	1	1		
	12:00	2,340				1	1	1		
	13:00	2,340				1	1	1		
	14:00	2,290				1	1	1		
	15:00	2,236				1	1	1		
	16:00	2,217				1	1	1		
	17:00	2,314				1	1	1		
	18:00	2,539				1	1	1		
	19:00	2,823				1	1	1	1	
	20:00	2,958				1	1	1	1	
	21:00	2,958				1	1	1	1	
	22:00	2,723				1	1	1	1	
	23:00	2,578				1	1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Δευτέρα, 6 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Δευτέρα, 6 Ιουλίου 2026	00:00	2,309				1	1	1		
	01:00	2,128				1	1	1		
	02:00	1,966				1	1	1		
	03:00	1,861				1	1	1		
	04:00	1,822				1	1	1		
	05:00	1,840				1	1	1		
	06:00	1,893				1	1	1		
	07:00	1,976				1	1	1		
	08:00	2,097				1	1	1		
	09:00	2,214				1	1	1		
	10:00	2,264				1	1	1		
	11:00	2,196				1	1	1		
	12:00	2,238				1	1	1		
	13:00	2,294				1	1	1		
	14:00	2,255				1	1	1		
	15:00	2,147				1	1	1		
	16:00	2,123				1	1	1		
	17:00	2,232				1	1	1		
	18:00	2,455				1	1	1		
	19:00	2,740				1	1	1	1	
	20:00	2,907				1	1	1	1	
	21:00	2,904				1	1	1	1	
	22:00	2,698				1	1	1	1	
	23:00	2,533				1	1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τρίτη, 7 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τρίτη, 7 Ιουλίου 2026	00:00	2,166				1	1	1		
	01:00	1,946				1	1	1		
	02:00	1,795				1	1	1		
	03:00	1,727				1	1	1		
	04:00	1,715				1	1	1		
	05:00	1,724				1	1	1		
	06:00	1,750				1	1	1		
	07:00	1,917				1	1	1		
	08:00	2,039				1	1	1		
	09:00	2,082				1	1	1		
	10:00	2,092				1	1	1		
	11:00	2,125				1	1	1		
	12:00	2,249				1	1	1		
	13:00	2,383				1	1	1		
	14:00	2,375				1	1	1		
	15:00	2,237				1	1	1		
	16:00	2,165				1	1	1		
	17:00	2,222				1	1	1		
	18:00	2,424				1	1	1		
	19:00	2,672				1	1	1	1	
	20:00	2,836				1	1	1	1	
	21:00	2,844				1	1	1	1	
	22:00	2,712				1	1	1	1	
	23:00	2,526				1	1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Τετάρτη, 8 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Σ Κ Υ Ρ Ο Υ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Τετάρτη, 8 Ιουλίου 2026	00:00	2,162				1	1	1		
	01:00	1,954				1	1	1		
	02:00	1,843				1	1	1		
	03:00	1,776				1	1	1		
	04:00	1,709				1	1	1		
	05:00	1,638				1	1	1		
	06:00	1,592				1	1	1		
	07:00	1,716				1	1	1		
	08:00	1,956				1	1	1		
	09:00	2,110				1	1	1		
	10:00	2,161				1	1	1		
	11:00	2,230				1	1	1		
	12:00	2,362				1	1	1		
	13:00	2,507				1	1	1		
	14:00	2,561				1	1	1		
	15:00	2,416				1	1	1		
	16:00	2,282				1	1	1		
	17:00	2,276				1	1	1		
	18:00	2,447				1	1	1		
	19:00	2,720				1	1	1	1	
	20:00	2,983				1	1	1	1	
	21:00	3,063				1	1	1	1	
	22:00	2,911				1	1	1	1	
	23:00	2,643				1	1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Προτεινόμενος ΗΕΠ				Πέμπτη, 9 Ιουλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,900	1,000	1,000	1,000	1,000	1,000	1,000	0,900	1,000
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	HZ (x1)
Πέμπτη, 9 Ιουλίου 2026	00:00	2,415				1	1	1		
	01:00	2,170				1	1	1		
	02:00	2,021				1	1	1		
	03:00	1,924				1	1	1		
	04:00	1,836				1	1	1		
	05:00	1,821				1	1	1		
	06:00	1,804				1	1	1		
	07:00	1,923				1	1	1		
	08:00	2,052				1	1	1		
	09:00	2,089				1	1	1		
	10:00	2,095				1	1	1		
	11:00	2,143				1	1	1		
	12:00	2,251				1	1	1		
	13:00	2,400				1	1	1		
	14:00	2,489				1	1	1		
	15:00	2,397				1	1	1		
	16:00	2,288				1	1	1		
	17:00	2,303				1	1	1		
	18:00	2,486				1	1	1		
	19:00	2,789				1	1	1	1	
	20:00	3,051				1	1	1	1	
	21:00	2,983				1	1	1	1	
	22:00	2,786				1	1	1	1	
	23:00	2,507				1	1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης