

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Τετάρτη, 12 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 12 Αυγούστου 2026	00:00	126	1				1		
	01:00	119	1				1		
	02:00	117	1				1		
	03:00	116	1				1		
	04:00	115	1				1		
	05:00	113	1				1		
	06:00	107	1				1		
	07:00	104	1				1		
	08:00	107	1				1		
	09:00	114	1				1		
	10:00	121	1				1		
	11:00	127	1				1		
	12:00	133	1				1		
	13:00	137	1				1		
	14:00	139	1				1		
	15:00	138	1				1		
	16:00	137	1				1		
	17:00	134	1				1		
	18:00	129	1				1		
	19:00	123	1				1		
	20:00	125	1				1		
	21:00	129	1				1		
	22:00	131	1				1		
	23:00	132	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Πέμπτη, 13 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 13 Αυγούστου 2026	00:00	126	1				1		
	01:00	120	1				1		
	02:00	118	1				1		
	03:00	116	1				1		
	04:00	114	1				1		
	05:00	112	1				1		
	06:00	108	1				1		
	07:00	105	1				1		
	08:00	104	1				1		
	09:00	110	1				1		
	10:00	119	1				1		
	11:00	126	1				1		
	12:00	129	1				1		
	13:00	130	1				1		
	14:00	133	1				1		
	15:00	131	1				1		
	16:00	130	1				1		
	17:00	127	1				1		
	18:00	124	1				1		
	19:00	119	1				1		
	20:00	122	1				1		
	21:00	126	1				1		
	22:00	130	1				1		
	23:00	130	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Παρασκευή, 14 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 14 Αυγούστου 2026	00:00	121	1				1		
	01:00	114	1				1		
	02:00	109	1				1		
	03:00	105	1				1		
	04:00	104	1				1		
	05:00	102	1				1		
	06:00	100	1				1		
	07:00	98	1				1		
	08:00	99	1				1		
	09:00	104	1				1		
	10:00	110	1				1		
	11:00	116	1				1		
	12:00	121	1				1		
	13:00	124	1				1		
	14:00	127	1				1		
	15:00	129	1				1		
	16:00	129	1				1		
	17:00	128	1				1		
	18:00	122	1				1		
	19:00	116	1				1		
	20:00	120	1				1		
	21:00	126	1				1		
	22:00	130	1				1		
	23:00	127	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Σάββατο, 15 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)			110	110	110	100	100	100	150
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 15 Αυγούστου 2026	00:00	122	1				1		
	01:00	113	1				1		
	02:00	106	1				1		
	03:00	102	1				1		
	04:00	99	1				1		
	05:00	99	1				1		
	06:00	100	1				1		
	07:00	103	1				1		
	08:00	107	1				1		
	09:00	111	1				1		
	10:00	116	1				1		
	11:00	120	1				1		
	12:00	123	1				1		
	13:00	124	1				1		
	14:00	127	1				1		
	15:00	129	1				1		
	16:00	132	1				1		
	17:00	131	1				1		
	18:00	128	1				1		
	19:00	123	1				1		
	20:00	125	1				1		
	21:00	129	1				1		
	22:00	134	1				1		
	23:00	132	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Κυριακή, 16 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 16 Αυγούστου 2026	00:00	125	1				1		
	01:00	119	1				1		
	02:00	115	1				1		
	03:00	113	1				1		
	04:00	111	1				1		
	05:00	108	1				1		
	06:00	103	1				1		
	07:00	100	1				1		
	08:00	101	1				1		
	09:00	107	1				1		
	10:00	115	1				1		
	11:00	120	1				1		
	12:00	125	1				1		
	13:00	128	1				1		
	14:00	130	1				1		
	15:00	130	1				1		
	16:00	130	1				1		
	17:00	128	1				1		
	18:00	125	1				1		
	19:00	121	1				1		
	20:00	121	1				1		
	21:00	125	1				1		
	22:00	131	1				1		
	23:00	131	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Δευτέρα, 17 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 17 Αυγούστου 2026	00:00	123	1				1		
	01:00	115	1				1		
	02:00	110	1				1		
	03:00	107	1				1		
	04:00	106	1				1		
	05:00	104	1				1		
	06:00	101	1				1		
	07:00	101	1				1		
	08:00	106	1				1		
	09:00	114	1				1		
	10:00	120	1				1		
	11:00	125	1				1		
	12:00	129	1				1		
	13:00	131	1				1		
	14:00	132	1				1		
	15:00	131	1				1		
	16:00	129	1				1		
	17:00	128	1				1		
	18:00	126	1				1		
	19:00	123	1				1		
	20:00	123	1				1		
	21:00	126	1				1		
	22:00	130	1				1		
	23:00	130	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ		Τρίτη, 18 Αυγούστου 2026					
Αποδιδόμενη Ισχύς (kW)		110	110	110	100	100	100	150	
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 18 Αυγούστου 2026	00:00	128	1				1		
	01:00	118	1				1		
	02:00	112	1				1		
	03:00	109	1				1		
	04:00	108	1				1		
	05:00	107	1				1		
	06:00	106	1				1		
	07:00	104	1				1		
	08:00	105	1				1		
	09:00	110	1				1		
	10:00	119	1				1		
	11:00	127	1				1		
	12:00	132	1				1		
	13:00	133	1				1		
	14:00	134	1				1		
	15:00	134	1				1		
	16:00	132	1				1		
	17:00	130	1				1		
	18:00	128	1				1		
	19:00	126	1				1		
	20:00	128	1				1		
	21:00	133	1				1		
	22:00	137	1				1		
	23:00	136	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης