

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 12 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Τετάρτη, 12 Αυγούστου 2026	00:00	2,474	1	1		1			
	01:00	2,274	1	1		1			
	02:00	2,142	1	1		1			
	03:00	2,050	1	1		1			
	04:00	1,982	1	1		1			
	05:00	1,944	1	1		1			
	06:00	1,963	1	1		1			
	07:00	2,048	1	1		1			
	08:00	2,181	1	1		1			
	09:00	2,346	1	1		1			
	10:00	2,451	1	1		1			
	11:00	2,494	1	1		1			
	12:00	2,524	1	1	1	1			
	13:00	2,556	1	1	1	1			
	14:00	2,577	1	1	1	1			
	15:00	2,555	1	1	1	1			
	16:00	2,549	1	1	1	1			
	17:00	2,607	1	1	1	1			
	18:00	2,740	1	1	1	1			
	19:00	2,933	1	1	1	1			
	20:00	3,094	1	1	1	1			
	21:00	3,119	1	1	1	1			
	22:00	2,957	1	1	1	1			
	23:00	2,716	1	1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 13 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Σ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Πέμπτη, 13 Αυγούστου 2026	00:00	2,419	1	1		1			
	01:00	2,230	1	1		1			
	02:00	2,104	1	1		1			
	03:00	2,018	1	1		1			
	04:00	1,950	1	1		1			
	05:00	1,906	1	1		1			
	06:00	1,919	1	1		1			
	07:00	1,991	1	1		1			
	08:00	2,117	1	1		1			
	09:00	2,307	1	1		1			
	10:00	2,416	1	1		1			
	11:00	2,466	1	1		1			
	12:00	2,494	1	1		1			
	13:00	2,512	1	1	1	1			
	14:00	2,529	1	1	1	1			
	15:00	2,522	1	1	1	1			
	16:00	2,525	1	1	1	1			
	17:00	2,587	1	1	1	1			
	18:00	2,732	1	1	1	1			
	19:00	2,922	1	1	1	1			
	20:00	3,074	1	1	1	1			
	21:00	3,088	1	1	1	1			
	22:00	2,924	1	1	1	1			
	23:00	2,686	1	1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 14 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Παρασκευή, 14 Αυγούστου 2026	00:00	2,384	1	1		1			
	01:00	2,197	1	1		1			
	02:00	2,066	1	1		1			
	03:00	1,980	1	1		1			
	04:00	1,914	1	1		1			
	05:00	1,872	1	1		1			
	06:00	1,886	1	1		1			
	07:00	1,914	1	1		1			
	08:00	2,046	1	1		1			
	09:00	2,233	1	1		1			
	10:00	2,372	1	1		1			
	11:00	2,423	1	1		1			
	12:00	2,449	1	1		1			
	13:00	2,460	1	1		1			
	14:00	2,461	1	1		1			
	15:00	2,425	1	1		1			
	16:00	2,401	1	1		1			
	17:00	2,445	1	1		1			
	18:00	2,583	1	1	1	1			
	19:00	2,778	1	1	1	1			
	20:00	2,931	1	1	1	1			
	21:00	2,937	1	1	1	1			
	22:00	2,779	1	1	1	1			
	23:00	2,539	1	1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 15 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Σάββατο, 15 Αυγούστου 2026	00:00	2,217	1	1		1			
	01:00	2,054	1	1		1			
	02:00	1,962	1	1		1			
	03:00	1,905	1	1		1			
	04:00	1,861	1	1		1			
	05:00	1,823	1	1		1			
	06:00	1,811	1	1		1			
	07:00	1,842	1	1		1			
	08:00	1,936	1	1		1			
	09:00	2,105	1	1		1			
	10:00	2,273	1	1		1			
	11:00	2,366	1	1		1			
	12:00	2,429	1	1		1			
	13:00	2,445	1	1		1			
	14:00	2,419	1	1		1			
	15:00	2,370	1	1		1			
	16:00	2,337	1	1		1			
	17:00	2,394	1	1		1			
	18:00	2,541	1	1	1	1			
	19:00	2,742	1	1	1	1			
	20:00	2,873	1	1	1	1			
	21:00	2,855	1	1	1	1			
	22:00	2,684	1	1	1	1			
	23:00	2,436	1	1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 16 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Κυριακή, 16 Αυγούστου 2026	00:00	2,124	1	1		1			
	01:00	1,967	1	1		1			
	02:00	1,877	1	1		1			
	03:00	1,814	1	1		1			
	04:00	1,763	1	1		1			
	05:00	1,732	1	1		1			
	06:00	1,741	1	1		1			
	07:00	1,815	1	1		1			
	08:00	1,933	1	1		1			
	09:00	2,096	1	1		1			
	10:00	2,256	1	1		1			
	11:00	2,362	1	1		1			
	12:00	2,410	1	1		1			
	13:00	2,419	1	1		1			
	14:00	2,380	1	1		1			
	15:00	2,312	1	1		1			
	16:00	2,276	1	1		1			
	17:00	2,315	1	1		1			
	18:00	2,445	1	1		1			
	19:00	2,646	1	1	1	1			
	20:00	2,792	1	1	1	1			
	21:00	2,776	1	1	1	1			
	22:00	2,602	1	1	1	1			
	23:00	2,346	1	1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 17 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Δευτέρα, 17 Αυγούστου 2026	00:00	2,115	1	1		1			
	01:00	1,940	1	1		1			
	02:00	1,823	1	1		1			
	03:00	1,742	1	1		1			
	04:00	1,688	1	1		1			
	05:00	1,668	1	1		1			
	06:00	1,700	1	1		1			
	07:00	1,802	1	1		1			
	08:00	1,931	1	1		1			
	09:00	2,111	1	1		1			
	10:00	2,274	1	1		1			
	11:00	2,357	1	1		1			
	12:00	2,394	1	1		1			
	13:00	2,398	1	1		1			
	14:00	2,379	1	1		1			
	15:00	2,321	1	1		1			
	16:00	2,272	1	1		1			
	17:00	2,303	1	1		1			
	18:00	2,424	1	1		1			
	19:00	2,614	1	1	1	1			
	20:00	2,757	1	1	1	1			
	21:00	2,745	1	1	1	1			
	22:00	2,562	1	1	1	1			
	23:00	2,309	1	1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 18 Αυγούστου 2026				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X2)
Τρίτη, 18 Αυγούστου 2026	00:00	2,059	1	1		1			
	01:00	1,903	1	1		1			
	02:00	1,800	1	1		1			
	03:00	1,731	1	1		1			
	04:00	1,680	1	1		1			
	05:00	1,657	1	1		1			
	06:00	1,688	1	1		1			
	07:00	1,792	1	1		1			
	08:00	1,930	1	1		1			
	09:00	2,101	1	1		1			
	10:00	2,249	1	1		1			
	11:00	2,328	1	1		1			
	12:00	2,362	1	1		1			
	13:00	2,371	1	1		1			
	14:00	2,367	1	1		1			
	15:00	2,331	1	1		1			
	16:00	2,295	1	1		1			
	17:00	2,317	1	1		1			
	18:00	2,422	1	1		1			
	19:00	2,590	1	1	1	1			
	20:00	2,717	1	1	1	1			
	21:00	2,700	1	1	1	1			
	22:00	2,528	1	1	1	1			
	23:00	2,282	1	1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης / προς απόσυρση