

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 1 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Σάββατο, 1 Αυγούστου 2026	00:00	45,92			1	1	1	1		1		1		17
	01:00	40,00			1	1	1	1		1		1		13
	02:00	40,65			1	1	1	1		1		1		10
	03:00	38,76			1	1	1	1		1		1		9
	04:00	37,84			1	1	1	1		1		1		9
	05:00	37,53			1	1	1	1		1		1		9
	06:00	38,37			1	1	1	1		1		1		9
	07:00	42,37			1	1	1	1		1		1		11
	08:00	47,02			1	1	1	1		1		1		16
	09:00	50,88			1	1	1	1		1		1		19
	10:00	53,12			1	1	1	1		1		1	2	20
	11:00	54,13			1	1	1	1		1		1	3	20
	12:00	56,09			1	1	1	1		1		1	4	20
	13:00	57,40			1	1	1	1		1		1	7	20
	14:00	57,45			1	1	1	1		1		1	7	20
	15:00	56,61			1	1	1	1		1		1	8	20
	16:00	55,52			1	1	1	1		1		1	6	20
	17:00	55,49			1	1	1	1		1		1	6	20
	18:00	56,51			1	1	1	1		1		1	6	20
	19:00	55,87			1	1	1	1		1		1	6	20
	20:00	55,27			1	1	1	1		1		1	6	20
	21:00	54,81			1	1	1	1		1		1	6	20
	22:00	52,83			1	1	1	1		1		1	4	20
	23:00	48,97			1	1	1	1		1		1	1	20

Τρία φορητά H/Z βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης