

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας		Κυριακή, 2 Αυγούστου 2026											
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000	
Η Ρ Α Κ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)	
Κυριακή, 2 Αυγούστου 2026	00:00	44,82			1	1	1	1		1		1		16	
	01:00	41,86			1	1	1	1		1		1		13	
	02:00	39,48			1	1	1	1		1		1		10	
	03:00	38,05			1	1	1	1		1		1		9	
	04:00	37,81			1	1	1	1		1		1		8	
	05:00	37,38			1	1	1	1		1		1		8	
	06:00	38,28			1	1	1	1		1		1		8	
	07:00	42,55			1	1	1	1		1		1		12	
	08:00	46,59			1	1	1	1		1	1	1		14	
	09:00	49,74			1	1	1	1		1	1	1		13	
	10:00	52,30			1	1	1	1		1	1	1		13	
	11:00	53,65			1	1	1	1		1	1	1		13	
	12:00	55,65			1	1	1	1		1	1	1		15	
	13:00	56,50				1	1	1	1		1	1	1		16
	14:00	56,24				1	1	1	1		1	1	1	2	16
	15:00	55,54				1	1	1	1		1	1	1		18
	16:00	54,78				1	1	1	1		1	1	1		18
	17:00	55,17				1	1	1	1		1	1	1		18
	18:00	55,20				1	1	1	1		1	1	1		18
	19:00	55,19				1	1	1	1		1	1	1		18
	20:00	54,52				1	1	1	1		1	1	1		18
	21:00	54,76				1	1	1	1		1	1	1		18
	22:00	53,09				1	1	1	1		1	1	1		17
	23:00	48,95				1	1	1	1		1	1	1		13

Δοκιμαστική λειτουργία G2. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης