

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 3 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Δευτέρα, 3 Αυγούστου 2026	00:00	45,31			1	1	1	1		1	1	1		9
	01:00	42,11			1	1	1	1		1	1	1		5
	02:00	39,78			1	1	1	1		1	1	1		
	03:00	38,32			1	1	1	1		1	1	1		
	04:00	38,06			1	1	1	1		1	1	1		
	05:00	37,72			1	1	1	1		1	1	1		
	06:00	38,95			1	1	1	1		1	1	1		
	07:00	43,96			1	1	1	1		1	1	1		5
	08:00	48,70			1	1	1	1		1	1	1		10
	09:00	52,32			1	1	1	1	1	1	1	1	1	14
	10:00	55,07			1	1	1	1	1		1	1		19
	11:00	56,91			1	1	1	1	1		1	1		20
	12:00	58,78			1	1	1	1	1		1	1		19
	13:00	59,92			1	1	1	1	1		1	1		19
	14:00	59,30			1	1	1	1	1		1	1		20
	15:00	58,72			1	1	1	1	1		1	1		20
	16:00	57,86			1	1	1	1	1		1	1		19
	17:00	57,97			1	1	1	1	1		1	1		20
	18:00	58,31			1	1	1	1	1		1	1		20
	19:00	57,85			1	1	1	1	1		1	1		20
	20:00	56,90			1	1	1	1	1		1	1		20
	21:00	56,99			1	1	1	1	1		1	1		20
	22:00	55,00			1	1	1	1	1		1	1		18
	23:00	50,77			1	1	1	1	1		1	1		14

Τρία φορητά H/Z βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης