

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 4 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Τρίτη, 4 Αυγούστου 2026	00:00	46,52			1	1	1	1	1		1	1		9
	01:00	42,71			1	1	1	1	1		1	1		5
	02:00	40,28			1	1	1	1	1		1	1		
	03:00	39,57			1	1	1	1	1		1	1		
	04:00	39,01			1	1	1	1	1		1	1		
	05:00	38,27			1	1	1	1	1		1	1		
	06:00	39,15			1	1	1	1	1		1	1		
	07:00	44,25			1	1	1	1	1		1	1		5
	08:00	49,15	1	1	1	1	1		1	1		10		
	09:00	52,46	1	1	1	1	1	1	1	1	1		13	
	10:00	55,69	1	1	1	1	1	1	1	1	1		13	
	11:00	56,98	1	1	1	1	1	1	1	1	1		15	
	12:00	58,86	1	1	1	1	1	1	1	1	1		17	
	13:00	60,40	1	1	1	1	1	1	1	1	1		17	
	14:00	60,63	1	1	1	1	1	1	1	1	1		17	
	15:00	59,52	1	1	1	1	1	1	1	1	1		17	
	16:00	58,76	1	1	1	1	1	1	1	1	1		17	
	17:00	58,93	1	1	1	1	1	1	1	1	1		17	
	18:00	59,49	1	1	1	1	1	1	1	1	1		17	
	19:00	59,21	1	1	1	1	1	1	1	1	1	1	18	
	20:00	58,16	1		1	1	1	1	1	1	1		19	
	21:00	58,17	1		1	1	1	1	1	1	1		19	
	22:00	55,94	1		1	1	1	1	1	1	1		17	
	23:00	51,92	1		1	1	1	1	1	1	1		13	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης