

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας		Τετάρτη, 5 Αυγούστου 2026											
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000	
ΗΡΑΣ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)	
Τετάρτη, 5 Αυγούστου 2026	00:00	47,27		1		1	1	1	1		1	1		8	
	01:00	43,85		1		1	1	1	1	1		1	1		4
	02:00	41,53		1		1	1	1	1	1		1	1		
	03:00	40,16		1		1	1	1	1	1		1	1		
	04:00	39,71		1		1	1	1	1	1		1	1		
	05:00	39,79		1		1	1	1	1	1		1	1		
	06:00	40,11		1		1	1	1	1	1		1	1		
	07:00	44,48		1		1	1	1	1	1		1	1		4
	08:00	49,77		1		1	1	1	1	1		1	1		9
	09:00	54,46		1		1	1	1	1	1		1	1		13
	10:00	56,37	1	1	1	1	1	1		1	1		14		
	11:00	57,39	1	1	1	1	1	1		1	1		14		
	12:00	59,08	1	1	1	1	1	1		1	1		13		
	13:00	60,75	1	1	1	1	1	1		1	1		13		
	14:00	61,16	1	1	1	1	1	1		1	1		13		
	15:00	59,81	1	1	1	1	1	1		1	1		13		
	16:00	59,24	1	1	1	1	1	1		1	1		13		
	17:00	59,49	1	1	1	1	1	1		1	1		13		
	18:00	59,74	1	1	1	1	1	1		1	1		13		
	19:00	58,81	1	1	1	1	1	1		1	1		13		
	20:00	58,08	1	1	1	1	1	1		1	1		13		
	21:00	58,23	1	1	1	1	1	1		1	1		11		
	22:00	56,17	1	1	1	1	1	1		1	1		11		
	23:00	52,26	1	1	1	1	1	1		1	1		6		

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης