

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 6 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Πέμπτη, 6 Αυγούστου 2026	00:00	47,34	1	1	1	1	1	1	1		1	1		1
	01:00	44,18	1	1	1	1	1	1	1		1	1		
	02:00	42,27	1	1	1	1	1	1	1		1	1	1	
	03:00	41,01	1	1	1	1	1	1	1			1	1	
	04:00	39,98	1	1	1	1	1	1	1			1		
	05:00	40,10	1	1	1	1	1	1	1			1		
	06:00	39,98	1	1	1	1	1	1	1			1		
	07:00	44,37	1	1	1	1	1	1	1		1	1		2
	08:00	50,43	1	1	1	1	1	1	1		1	1		3
	09:00	54,46	1	1	1	1	1	1	1		1	1		9
	10:00	56,49	1	1	1	1	1	1	1		1	1		8
	11:00	58,27	1	1	1	1	1	1	1		1	1		9
	12:00	60,79	1	1	1	1	1	1	1		1	1		11
	13:00	62,25	1	1	1	1	1	1	1		1	1		13
	14:00	62,02	1	1	1	1	1	1	1		1	1		14
	15:00	61,21	1	1	1	1	1	1	1		1	1		14
	16:00	60,72	1	1	1	1	1	1	1		1	1		14
	17:00	60,02	1	1	1	1	1	1	1		1	1		14
	18:00	60,83	1	1	1	1	1	1	1		1	1		14
	19:00	60,19	1	1	1	1	1	1	1		1	1		14
	20:00	58,95	1	1	1	1	1	1	1		1	1		14
	21:00	58,57	1	1	1	1	1	1	1		1	1		14
	22:00	56,62	1	1	1	1	1	1	1		1	1		13
	23:00	52,31	1	1	1	1	1	1	1		1	1		9

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης