

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 10 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	νοικ. H/ (x20)
Δευτέρα, 10 Αυγούστου 2026	00:00	49,92	1	1	1	1			1		1	1		9
	01:00	46,20	1	1	1	1			1		1	1		5
	02:00	42,98	1	1	1	1			1		1	1		2
	03:00	41,39	1	1	1	1			1		1	1		
	04:00	40,84	1	1	1	1			1		1	1		
	05:00	40,24	1	1	1	1			1		1	1		
	06:00	41,69	1	1	1	1			1		1	1		
	07:00	46,10	1	1	1	1			1		1	1		3
	08:00	51,38	1	1	1	1			1		1	1		9
	09:00	55,64	1	1	1	1			1		1	1		13
	10:00	57,95	1	1	1	1			1		1	1		16
	11:00	59,89	1	1	1	1			1		1	1		16
	12:00	62,04	1	1	1	1	1		1		1	1		17
	13:00	63,40	1	1	1	1	1		1		1	1		18
	14:00	63,58	1	1	1	1	1		1		1	1		18
	15:00	62,83	1	1	1	1	1		1		1	1		18
	16:00	62,10	1	1	1	1	1		1		1	1		18
	17:00	62,47	1	1	1	1	1		1		1	1		18
	18:00	63,09	1	1	1	1	1		1		1	1		18
	19:00	61,63	1	1	1	1	1		1		1	1		18
	20:00	60,83	1	1	1	1	1		1		1	1		18
	21:00	60,43	1	1	1	1	1		1		1	1		18
	22:00	58,23	1	1	1	1	1		1		1	1		17
	23:00	54,35	1	1	1	1	1		1		1	1		13

Τρία Η/Ζ βρίσκονται σε βλάβη. Μερική διακοπή στις 5:46 με 5:55 λόγω βλάβη στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης