

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 14 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Παρασκευή, 14 Αυγούστου 2026	00:00	50,45	1	1	1	1	1	1			1	1		9
	01:00	46,87	1	1	1	1	1	1			1	1		5
	02:00	44,19	1	1	1	1	1	1			1	1	2	4
	03:00	42,63	1		1	1	1	1			1	1	2	4
	04:00	41,63	1		1	1	1	1			1	1	2	4
	05:00	41,74	1		1	1	1	1			1	1		4
	06:00	42,21	1		1	1	1	1			1	1		4
	07:00	45,89	1		1	1	1	1			1	1		8
	08:00	50,79	1		1	1	1	1			1	1		12
	09:00	55,12	1	1	1	1	1	1			1	1		13
	10:00	57,67	1	1	1	1	1	1			1	1		14
	11:00	58,60	1	1	1	1	1	1			1	1		15
	12:00	60,64	1	1	1	1	1	1			1	1		17
	13:00	61,85	1	1	1	1	1	1			1	1		19
	14:00	61,63	1	1	1	1	1	1			1	1		20
	15:00	60,54	1	1	1	1	1	1			1	1		19
	16:00	60,44	1	1	1	1	1	1			1	1		18
	17:00	60,41	1	1	1	1	1	1			1	1		18
	18:00	60,86	1	1	1	1	1	1			1	1		19
	19:00	60,14	1	1	1	1	1	1			1	1		18
	20:00	59,41	1	1	1	1	1	1			1	1		17
	21:00	58,95	1	1	1	1	1	1			1	1		17
	22:00	56,20	1	1	1	1	1	1			1	1		14
	23:00	52,72	1	1	1	1	1	1			1	1		10

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης