

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 15 Αυγούστου 2026									
Αποδιδόμενη Ισχύς (MW)			6,500	6,500	3,500	3,500	3,500	5,500	7,453	9,234	10,150	10,150	0,900	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Ενοικ. H/Z (x20)
Σάββατο, 15 Αυγούστου 2026	00:00	48,21	1	1	1	1	1	1			1	1		5
	01:00	44,71	1	1	1	1	1	1			1	1		2
	02:00	42,96	1	1	1	1	1	1			1	1		
	03:00	41,72	1	1	1	1	1	1			1	1		
	04:00	40,35	1	1	1	1	1	1			1	1		
	05:00	40,40	1	1	1	1	1	1			1	1		
	06:00	41,38	1	1	1	1	1	1			1	1		
	07:00	44,57	1	1	1	1	1	1			1	1		4
	08:00	48,54	1	1	1	1	1	1			1	1		6
	09:00	51,39	1	1	1	1	1	1			1	1		8
	10:00	53,20	1	1	1	1	1	1			1	1		10
	11:00	53,81	1	1	1	1	1	1			1	1		11
	12:00	55,02	1	1	1	1	1	1			1	1		12
	13:00	56,00	1	1	1	1	1	1			1	1		13
	14:00	55,30	1	1	1	1	1	1			1	1		13
	15:00	54,84	1	1	1	1	1	1			1	1		13
	16:00	54,34	1	1	1	1	1	1			1	1		12
	17:00	54,66	1	1	1	1	1	1			1	1		12
	18:00	55,87	1	1	1	1	1	1			1	1		13
	19:00	55,73	1	1	1	1	1	1			1	1		13
	20:00	55,62	1	1	1	1	1	1			1	1		14
	21:00	55,41	1	1	1	1	1	1			1	1		14
	22:00	52,81	1	1	1	1	1	1			1	1		12
	23:00	49,38	1	1	1	1	1	1			1	1		7

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης